

QUARTERLY RELEASE REPORT

QUARTER: 1 and 2 YEAR: 1990

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of 5.0E-08 uCi/ml Sr-89 in liquid or 1.0E-11 uCi/cc in air. The Curie amounts released and the corresponding doses were calculated to be zero.

Airborne Composite Sr-89 Sample Results

RELEASE STACK	QTR 3 uCi/cc	QTR 4 uCi/cc
UII CONT	<1.1E-11	

Liquid Composite Sr-89 Sample Results

RELEASE PATH	QTR 1 uCi/ml	QTR 2 uCi/ml
UI TBS	<6.1E-08	
UII TBS	<6.1E-08	<8.9E-08
UI SGBD	<6.0E-08	
UII SGBD	<5.7E-08	
WASTE TANKS	<6.1E-08	
UI COND	<6.3E-08	
UII COND		