

## SEMI-ANNUAL REPORT ATTACHMENT

QUARTER: 1 and 2 YEAR: 1991

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of  $5.0\text{E-}08$  uCi/ml Sr-89 for liquid. The Curie amounts released and the corresponding doses were calculated to be zero.

## Liquid Composite Sample Results

RELEASE PATH	QTR 1 uCi/ml	QTR 2 uCi/ml
UI TBS		<7.4E-08
UII TBS		<5.9E-08
UI SGBD		<5.8E-08
UII SGBD	<7.4E-08	
WASTE TANKS		<5.6E-08
UI COND		<6.3E-08
UII COND		