

QUARTERLY RELEASE REPORT

QUARTER: 3 and 4 YEAR: 1991

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of $5.0E-08$ uCi/ml Sr-89 for liquid. The Curie amounts released and the corresponding doses were calculated to be zero.

Liquid Composite Sample Results

RELEASE PATH	QTR 3 uCi/ml	QTR 4 uCi/ml
UI TBS		
UII TBS	<5.4E-08	
UI SGBD		
UII SGBD		
WASTE TANKS	<8.0E-08	
UI COND	<8.0E-08	
UII COND		