

SEMI-ANNUAL REPORT ATTACHMENT

QUARTER: 1 and 2 YEAR: 1992

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of $5.0\text{E-}08$ uCi/ml Sr-89 for liquid. The Curie amounts released and the corresponding doses were calculated to be zero.

Liquid Composite Sample Results

RELEASE PATH	QTR 1 uCi/ml	QTR 2 uCi/ml
UI TBS	<8.6E-08	
UII TBS	<1.4E-07	
UI SGBD	<8.1E-08	
UII SGBD	<8.3E-08	
WASTE TANKS	<8.4E-08	
UI COND		
UII COND	<8.6E-08	