

## SEMI-ANNUAL REPORT ATTACHMENT

QUARTER: 3 and 4 YEAR: 1992

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of  $5.0\text{E-}08$  uCi/ml Sr-89 for liquid. The Curie amounts released and the corresponding doses were calculated to be zero.

## Liquid Composite Sr-89 Sample Results

RELEASE PATH	QTR 3 uCi/ml	QTR 4 uCi/ml
UI TBS	<6.5E-08	
UII TBS		
UI SGBD	<1.2E-07	
UII SGBD	<5.1E-08	<5.2E-08
WASTE TANKS	<5.3E-08	<5.1E-08
UI COND		
UII COND		<8.2E-08