

Georgia Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7122

C. K. McCoy  
Vice President, Nuclear  
Vogtle Project



August 27, 1993

LCV-0133

Docket Nos. 50-424  
50-425

Tac Nos. M85932  
M85933

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Vogtle Electric Generating Plant  
Engineered Safety Features Actuation System  
Revision to Surveillance Frequencies Technical Specifications Changes

Gentlemen:

Based on the results of an August 25, 1993, conference call with the NRC Staff, Georgia Power is proposing a revision to the surveillance frequencies technical specifications changes originally provided by letter dated March 1, 1993. This change affects technical specifications Action 14 of table 3.3-2, "Engineered Safety Features Actuation System Instrumentation", and is being proposed to establish consistent language between Actions 14, 22, and 25 of that table with regard to entering Hot Standby for various automatic logic and actuation relays with the number of operable channels one less than the required minimum.

With the number of operable channels one less than the Minimum Channels Operable requirement, the currently proposed Action 14 would require the plant to be in Hot Standby within 12 hours while the currently proposed Actions 22 and 25 would require the plant to restore the inoperable channel to operable status within 6 hours or be in Hot Standby within the next 6 hours. In both cases, the total time allowed by either action statement to reach Hot Standby is 12 hours. Therefore, the new wording being proposed for Action 14 is not substantive and is editorial in nature.


The newly proposed wording to Action 14 is enclosed using the page marked-up in GPC's previous submittal. No other information in GPC's previous submittal, including the 10 CFR 50.92 information, is affected or proposed to be modified. In accordance with 10 CFR 50.91, the designated state official will be sent a copy of this letter and the enclosure.

9309080217 930827  
PDR ADDCK 05000424  
PDR

Aool  
1/1

Mr. C. K. McCoy states that he is a Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company and that, to be best of his knowledge and belief, the facts set forth in this letter and this enclosure are true.


Respectively yours,  
GEORGIA POWER COMPANY



C. K. McCoy

  
Sworn to and subscribed before me

this 27<sup>th</sup> day of August, 1993

  
Notary Public

MY COMMISSION EXPIRES MAY 6, 1994

CKM/CRP

Enclosure

cc: Georgia Power Company  
J. B. Beasley, General Manager - Vogtle Electric Generating Plant

U. S. Nuclear Regulatory Commission  
D. S. Hood, Licensing Project Manager, NRR  
S. D. Ebnetter, Regional Administrator, Region II  
B. R. Bonser, Senior Resident Inspector - VEGP

State of Georgia  
Mr. J. D. Tanner, Commissioner, Department of Natural Resources