

TABLE 3.3-2 (Continued)

TABLE NOTATIONS

- a Trip function may be blocked in this MODE below the P-11 (Pressurizer Pressure Interlock) Setpoint.
- b Trip function automatically blocked above P-11 and may be blocked below P-11 when Safety Injection on low steam line pressure is not blocked.
- c During movement of irradiated fuel or movement of loads over irradiated fuel within containment.
- d ~~The provisions of Specification 3.9.4 are not applicable. Not used.~~
- e During movement of irradiated fuel or movement of loads over irradiated fuel.
- f Not applicable if one main steam isolation valve and associated bypass isolation valve per steamline is closed.
- g Containment Ventilation Radiation (RE-2565) is treated as one channel and is considered OPERABLE if the particulate (RE-2565A) and iodine monitors (RE-2565B) are OPERABLE or the noble gas monitor (RE-2565C) is OPERABLE.
- h Manual initiation of Auxiliary Feedwater is accomplished via the pump handswitches.
- i Whenever irradiated fuel is in either storage pool.
- j For actions associated with inoperable instrumentation, follow actions specified in Specification 3.9.12.

ACTION STATEMENTS

restore the inoperable channel to OPERABLE status within 6 hours, or

ACTION 14 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within ~~7~~ ⁴ hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to ~~2~~ ⁴ hours for surveillance testing per Specification 4.3.2.1, provided the other channel is OPERABLE.

ACTION 15 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed until performance of the next required ANALOG CHANNEL OPERATIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.

ACTION 16 - With the number of OPERABLE channels less than the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.9 (Mode 6).

With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is met. One additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.