

**Omaha Public Power District**

P.O. Box 399 Hwy. 75 - North of Ft. Calhoun Fort Calhoun, NE 68023-0399  
402/636-2000

August 31, 1993  
LIC-93-0230

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

References: 1. Docket No. 50-285  
2. LER 90-020 Revision 00 from OPPD (W. G. Gates) to NRC (Document Control Desk) dated October 15, 1990 (LIC-90-0804)

Gentlemen:

Subject: Licensee Event Report 90-020 Revision 01 for the Fort Calhoun Station

Please find attached Licensee Event Report (LER) 90-020 Revision 01 dated August 31, 1993. This revision updates the status of corrective actions and includes other minor editorial changes. Revisions to the Abstract and Text are denoted by vertical lines in the right margin. One specific change involves a corrective action which indicated that a modification request had been initiated to replace or upgrade diesel generator voltage regulators due to lack of spare parts availability. A review of this modification request has since concluded that such a modification is not required, in part because completion of modifications to increase reliability has reduced the need for a full complement of spare parts. As a result, the associated corrective action has been deleted from the LER.

This report is being submitted pursuant to 10 CFR 50.73(a)(2)(v). If you should have any questions, please contact me.

Sincerely,

*W. G. Gates*

W. G. Gates  
Vice President

WGG/jrg

Attachment

c: LeBoeuf, Lamb, Leiby & MacRae  
J. L. Milhoan, NRC Regional Administrator, Region IV  
S. D. Bloom, NRC Project Manager  
R. P. Mullikin, NRC Senior Resident Inspector  
INPO Records Center

9309080341 930831  
PDR ADOCK 05000285  
S PDR

*JE27*