



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 1223 • Elma, Washington 98541-1223 • (206) 482-4428

September 3, 1993
G03-93-127

Docket No. 50-508

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Gentlemen:

Subject: **NUCLEAR PROJECT NO. 3**
WNP-3 PRESERVATION PROGRAM

The Supply System has previously notified the NRC by letters G03-90-069, dated May 11, 1990, and G03-91-073, dated May 13, 1991, of the changes to the WNP-3 Preservation of Assets Program (WMC-051) identified through preservation experience and the improved environment within the plant buildings.

In order to demonstrate the site's effort to adjust the program in accordance with preservation experience and the continued improvement in the building environments, the following notable changes have been made to the document:

1. The Preservation Program was adjusted to reflect the installation of two desiccant type dehumidifiers for controlling relative humidity within the Reactor Auxiliary/Reactor Building superstructure. The use of dehumidifiers has allowed the Project to reduce its dependence on temperature elevation to control relative humidity.

140053

9309150031 930903
PDR ADOCK 05000508
A PDR

ADD 1/1

U. S. Nuclear Regulatory Commission


Page Two

NUCLEAR PROJECT NO. 3, WNP-3 PRESERVATION PROGRAM

2. The frequency of visual inspection of equipment and structures was reduced (Appendix A).
3. The use of supplemental heat in Category II environments was reduced (Appendix A).
4. The Corrosion Monitoring Program (CMP) walkdown frequency was adjusted from every 6 Months to annually (Appendix B).
5. The frequency of performing instrument calibration checks on the Preservation Program Sample was extended to every 2 years (Appendix D).
6. Appendix E, Oil and Lubricant Analysis and Trending During Plant Preservation, was issued as the fifth Appendix to WMC-051.

As in the past, we have provided an uncontrolled copy of the updated document for your review. If you have any questions or comments, please contact Mr. W. K. Drinkard, QA Manager, Phone (206) 482-4428, Extension 5330.

Sincerely,



G. C. Sorensen, Manager
Regulatory Programs

WKD/cae

Attachment

cc: Mr. W. L. Bryan, Washington Water Power Co. w/a
Mr. R. E. Dyer, Portland General Electric Co. w/a
Mr. J. R. Lauckhart, Puget Sound Power & Light Co. w/a
Mr. J. R. Lewis, Bonneville Power Administration w/a
Mr. D. P. Steinberg, PacifiCorp dba Pacific Power & Light Co. w/a
Ms. R. M. Jenkins, Ebasco - Elma w/o
Ebasco - New York w/o
Mr. M. M. Mendonca, U. S. Nuclear Regulatory Commission w/a
Mr. B. N. Faulkenberry, U. S. NRC, Region V Administrator w/a
Mr. N. S. Reynolds, Winston & Strawn w/a