

COMANCHE PEAK STEAM ELECTRIC STATION, UNIT 2
NRC MONTHLY OPERATING REPORT

REV. 2

DOCKET NO:	50-446
UNIT:	CPSES 2
DATE:	September 10, 1993
COMPLETED BY:	Janet Hughes
TELEPHONE:	817-897-5331

OPERATING STATUS

1. Reporting Period: JUNE 1993 Gross hours in reporting period: 720
2. Currently authorized power level (MWt): 3411 Max. depend. capacity (MWe-Net): 1150 * Design
Electrical Rating (MWe-Net): 1150
3. Power level to which restricted (if any) (MWe-Net): NONE
4. Reasons for restriction (if any):

	THIS MONTH	YR TO DATE	CUMULATIVE
5. Number of hours reactor was critical	0	834	834
6. Reactor reserve shutdown hours	720	1,138	1,138
7. Hours generator on line	0	787	787
8. Unit reserve shutdown hours	0	0	0
9. Gross thermal energy generated (MWH)	0	1,165,087	1,165,087
10. Gross electrical energy generated (MWH)	0	320,680	320,680
11. Net electrical energy generated (MWH)	0	268,787	268,787
12. Reactor Service factor	NA	NA	NA
13. Reactor availability factor	NA	NA	NA
14. Unit service factor	NA	NA	NA
15. Unit availability factor	NA	NA	NA
16. Unit capacity factor (Using MDC)	NA	NA	NA
17. Unit capacity factor (Using Design MWe)	NA	NA	NA
18. Unit forced outage rate	NA	NA	NA
19. Shutdowns scheduled over next 6 months (Type, Date, and Duration of each):			

20. If shutdown at end of report period, estimated date of startup:

21. Units in test status (prior to commercial operation):	FORECAST	ACHIEVED
Initial Criticality	<u>930320</u>	<u>930324</u>
Initial Electricity	<u>930330</u>	<u>930409</u>
Commercial Operation	<u>930801</u>	<u> </u>

* Estimated

JUNE 1993
REVISION 2