



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

Robert A. Fenech  
Vice President, Sequoyah Nuclear Plant

September 13, 1993

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - LICENSEE EVENT REPORT  
(LER) 50-327/92017, REVISION 1

The enclosed LER is being revised to provide the event cause as determined by a recently completed work document. The original LER provided details concerning an engineered safety feature (ESF) actuation as the result of an inadvertent auto start signal from the 1B-B centrifugal charging pump undervoltage auxiliary relay. This LER was originally submitted in accordance with 10 CFR 50.73(a)(2)(iv) as an automatic actuation of an ESF on September 30, 1992.

Revisions to the LER are annotated by vertical bars in the right-hand margin.

Sincerely,

Robert A. Fenech

Enclosure  
cc: See page 2

200041

9309210070 930913  
PDR ADOCK 05000327  
S PDR

JE28

U.S. Nuclear Regulatory Commission  
Page 2  
September 13, 1993

cc (Enclosure):

INPO Records Center  
Institute of Nuclear Power Operations  
700 Galleria Parkway  
Atlanta, Georgia 30339-5957

Mr. D. E. LaBarge, Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-2711