

REACTOR COOLANT SYSTEM

RELIEF VALVES

ATTACHMENT 2
ST-HL-AE-4176
PAGE 3 OF 8

SURVEILLANCE REQUIREMENTS

4.4.4.1 In addition to the requirements of Specification 4.0.5, each PORV shall be demonstrated OPERABLE at least once per 18 months by:

- a. Performing a CHANNEL CALIBRATION $\sqrt{\quad}$ and $\sqrt{\quad}$ on the actuation channel,
- b. Operating the valve through one complete cycle of full travel $\sqrt{\quad}$ during modes 3, 4, or 5.

4.4.4.2 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel unless the block valve is closed ~~with power removed~~ in order to meet the requirements of ACTION b. or c. in Specification 3.4.4.

Prior Submittal

REACTOR COOLANT SYSTEM

RELIEF VALVES

SURVEILLANCE REQUIREMENTS

4.4.4.1 In addition to the requirements of Specification 4.0.5, each PORV shall be demonstrated OPERABLE at least once per 18 months by:

- a. Performing a CHANNEL CALIBRATION ^{on the actuation channel} and
- b. Operating the valve through one complete cycle of full travel.

4.4.4.2 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel unless the block valve is closed ~~with power removed~~ in order to meet the requirements of ACTION b. or c. in Specification 3.4.4.

*(current) ORIGINAL to returned to.
(Annotated with GL90-06 changes unaffected by this submittal)*