

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of

Omaha Public Power District
(Fort Calhoun Station
Unit No. 1)

}
}
}
Docket No. 50-285

APPLICATION FOR AMENDMENT
OF
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission ("the Commission"), Omaha Public Power District, holder of Facility Operating License No. DPR-40, herewith requests that the Technical Specifications set forth in Appendix A to that License be amended to enable the current configuration of the Fuel Oil Supply System for the emergency diesel generators to meet the capacity requirements of IEEE-308 as being capable of providing fuel for 7 days of diesel generator operation following the most limiting accident.

The proposed changes in Technical Specifications are provided in Attachment A to this Application. A Discussion, Justification and No Significant Hazards Consideration Analysis, which demonstrates that the proposed changes do not involve significant hazards considerations, is appended in Attachment B. The proposed changes in specifications would not authorize any change in the types or any increase in the amounts of effluents that will be released, or a change in the authorized power level of the facility.

WHEREFORE, Applicant respectfully requests that Specification 2.7 and its basis of Appendix A to Facility Operating License No. DPR-40 be amended in the form attached hereto as Attachment A.

A copy of this Application, including its attachments, has been submitted to the Director - Nebraska State Division of Radiological Health, as required by 10 CFR 50.91.

OMAHA PUBLIC POWER DISTRICT

By *W. Gary Tule*
Vice President

Subscribed and sworn to before me this 17 day of September, 1993.

Carol J. Kelley
Notary Public

