

Ralph E. Reedle
Executive Vice President
Nuclear Generation

September 24, 1993
JPN-93-067

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Change to the Technical Specifications
Containment Cooling Subsystem Logic
Functional Test Clarification (JPTS-92-028)

Dear Sir,

This application for an amendment to the James A. FitzPatrick Technical Specifications revises Technical Specification Table 4.2-2 "Minimum Test and Calibration Frequency for Core and Containment Cooling Systems" to remove a testing requirement for the Containment Cooling Subsystem. Technical Specification Table 4.2-2, note 9 requires calibration of time delay relays and timers in the logic system functional test for the Containment Cooling Subsystem. The Containment Cooling Subsystem is manually initiated to remove heat from the containment in the event of testing, transients or accidents that add heat to the containment. It does not contain time delay relays or timers. The proposed change will remove this unnecessary test requirement.


The signed original of the Application for Amendment to Operating License is enclosed for filing. The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II. A markup of the affected Technical Specification pages is included as Attachment III.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being provided to the designated New York State official.

ADD 1

If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,



Ralph E. Beedle

att: as stated

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Brian C. McCabe
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223