



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987

Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN- 93135

October 4, 1993

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Reference: (a) Facility Operating License No. NPF-86, Docket No. 50-443
(b) NRC Letter SEA-93-025, "Inconsistent Technical Specification Surveillance Requirement, Electrical Power Systems, A.C. Sources", dated September 23, 1993, A.W. De Agazio to T.C. Feigenbaum

Subject: License Amendment Request 93-11: Emergency Diesel Generator Surveillance Requirements (TAC No. M87706)

Gentlemen:

North Atlantic Energy Service Corporation (North Atlantic) encloses herein License Amendment Request 93-11. This License Amendment Request is submitted pursuant to the requirements of 10CFR50.90 and to 10CFR50.4.

The purpose of License Amendment Request 93-11 is to propose changes to the Seabrook Station Technical Specifications. Currently the Technical Specifications require verification of both Emergency Diesel Generator speed and frequency. The proposed changes will correct an inconsistency within the Technical Specifications by deleting the requirement to verify Emergency Diesel Generator speed. The requirement to verify generator frequency remains unchanged. North Atlantic discussed the inconsistency and proposed License Amendment Request with representatives of the NRC on September 7 and 8, 1993.

License Amendment Request 93-11 has been reviewed and approved by the Station Operation Review Committee and the Nuclear Safety Audit Review Committee.

As discussed in the enclosed License Amendment Request, Section V, the proposed changes do not involve a significant hazards consideration pursuant to 10CFR50.92. A copy of this letter and the enclosed License Amendment Request have been forwarded to the State of New Hampshire State Liaison Officer pursuant to 10CFR50.91(b). In addition, North Atlantic has determined that License Amendment Request 93-11 meets the criteria of 10CFR51.22(c)(a) for a categorical exclusion from the requirements for an Environmental Impact Statement (see Section VII enclosed).

130055

9310150099 931004
PDR ADDCK 05000443
P PDR

member of the Northeast Utilities system

ADD 1


United States Nuclear Regulatory Commission
Attention: Document Control Desk

October 4, 1993
Page two

North Atlantic requests NRC review of License Amendment Request 93-11 and issuance of a license amendment by December 15, 1993 (see Section VI enclosed).

Should you have any questions regarding this letter, please contact Mr. Terry L. Harpster, Director of Licensing Services, at (603) 474-9521, extension 2765.

Very truly yours,



Ted C. Feigenbaum

Enclosure
TCF:MDO/tad

cc: Mr. Thomas T. Martin
Regional Administrator
United States Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Noel Dudley
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

Mr. George L. Iverson, Director
New Hampshire Office of Emergency Management
107 Pleasant Street
Concord, NH 03301