

Douglas R. Gipson  
Senior Vice President  
Nuclear Generation

Fermi 2  
6400 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-5249

Detroit  
Edison

October 8, 1993  
NRC-93-0107

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. D. 20555

- References: 1) Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43
- 2) Detroit Edison letter to NRC, "Proposed Technical Specification Change (License Amendment) - Charcoal Testing Standards for Control Room Emergency Filtration System and Standby Gas Treatment System," dated July 29, 1993

Subject: Transmittal of Design Calculation and Corrected  
Technical Specification Page

Attached please find Design Calculation 5549 Revision 0, "Control Room Dose from Fuel Handling Accident with CCHVAC Non-operational." This calculation is cited in Reference 2 and is being submitted as requested by Mr. Timothy Colburn of the NRC in a phone conversation of August 19, 1993.

A corrected Technical Specification page 3/4 7-8a for the Reference 2 submittal is also attached. ACTION C.2 has been corrected to cite the proper Surveillance Requirement for Control Room Emergency Filtration System duct leakage testing.

In the August 19 phone conversation it was also noted that Fermi 2 Technical Specification page 3/4 7-8 for the Control Room Emergency Filtration System was not updated when Amendment 88 to Fermi 2 Operating License was issued. Specifically, Surveillance Requirements 4.7.2.c and 4.7.2.d contained in a footnote should have been renumbered as 4.7.2.1.c and 4.7.2.1.d respectively to correspond to numbering changes made in Amendment 88. We request that this discrepancy be corrected through the issuance of an errata.

130032

9310150153 931008  
PDR ADOCK 05000341  
P FDR

A001  
11/1

USNRC


October 8, 1993

NRC-93-0107

Page 2

If you have any questions on these matters, please contact Mr. Glen D. Ohlemacher at (313) 586-4275.

Sincerely,



Attachment

cc: T. G. Colburn  
W. J. Kropp  
J. B. Martin  
M. P. Phillips