

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Rochester Gas and Electric Corporation) Docket No. 50-244
(R.E. Ginna Nuclear Power Plant))
)

**APPLICATION FOR AMENDMENT
TO OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Facility Operating License No. DPR-18, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended. This request for change in Technical Specifications is submitted to eliminate the steam flow/feed flow reactor trip.

The proposed Technical Specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. This evaluation also demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility. As demonstrated in Attachment B, the proposed change does not involve a significant hazards consideration.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation

By Robert C. Mecredy
Robert C. Mecredy
Vice President
Ginna Nuclear Production

Subscribed and sworn to before me
on this 2nd day of October, 1990.

Samuel H. Browne

SAMUEL H. BROWNE
NOTARY PUBLIC, State of New York
Registration No. 0017041
Qualified in Monroe City / Wayne City,
My Commission Expires Dec. 23, 1991