

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 6 1 6 8 2 8 0 7 1 4 8 2 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 2012 hours, June 16, 1982, during routine surveillance, an operator discovered 4  
0 3 primary Emergency Core Cooling System heat tracing circuits reading less than required  
0 4 by the Technical Specification. The channel was declared inoperable, and Action  
0 5 Statement 3.5.4.2 was entered. The secondary circuits were all operable, and the  
0 6 event constituted operation in a degraded mode in accordance with Technical Speci-  
0 7 fication 6.9.1.9.b.

0 8 7 8 9

0 9 SYSTEM CODE S F 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16

LER/RO  
REPORT  
NUMBEREVENT YEAR  
8 2  
21 22SEQUENTIAL  
REPORT NO.  
0 5 3  
23 24 25 26OCCURRENCE  
CODE  
0 3  
27 28 29REPORT  
TYPE  
L  
30 31REVISION  
NO.  
0  
32 33ACTION  
TAKEN  
B 18  
34 35FUTURE  
ACTION  
Z 19  
36 37EFFECT  
ON PLANT  
Z 20  
38 39SHUTDOWN  
METHOD  
Z 21  
40 41HOURS  
0 0 0  
42 43 44ATTACHMENT  
SUBMITTED  
Y 23  
45 46NPRD-4  
FORM SUB.  
N 24  
47 48PRIME COMP.  
SUPPLIER  
A 25  
49 50COMPONENT  
MANUFACTURER  
X 9 9 9 26  
51 52 53 54

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The supply breaker to the heat tracing was found to be in the tripped position. The  
1 1 breaker was reset and circuit currents were determined to be normal. One primary  
1 2 circuit had a damaged thermocouple junction, resulting from personnel standing on  
1 3 piping and lagging. The junction was repaired and no other problems which could have  
1 4 caused the breaker trip were discovered.

1 5 FACILITY STATUS E 28 1 0 0 29 OTHER STATUS (30) NA METHOD OF DISCOVERY B 31 Surveillance Testing DISCOVERY DESCRIPTION (32)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA (39)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA (41)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA (43)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

2 0 PUBLICITY ISSUED DESCRIPTION NA (45) 8207260305 820714 PDR ADOCK 05000311 S PDR  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

NAME OF PREPARER R. Trahm

PHONE (609) 541-5900 629