

CONTROL BLOCK:

--	--	--	--	--	--

 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

SYSTEM CODE 0 9		CAUSE CODE I A (11)		CAUSE SUBCODE E (12)		COMPONENT CODE B (13)		COMPONENT SUBCODE I N S T R U (14)		COMP. SUBCODE S (15)		VALVE SUBCODE Z (16)	
LER/RO REPORT NUMBER (17) 8 2		EVENT YEAR 21 22		SEQUENTIAL REPORT NO. 0 2 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0			
ACTION TAKEN E (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. Y (24)	
										PRIME COMP. SUPPLIER N (25)		COMPONENT MANUFACTURER E 0 6 9 (26)	

ISSUED DESCRIPTION (45) PDR 280308 820712
S ADCK 05000249

PHONE: (815) 942-2920, ext. 5290



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 3 - 82 - 41
STA UNIT YEAR NO.

PART 1	TITLE OF DEVIATION	OCCURRED	6/28/82	1115
Turb. 1st Stage Press. Sw. 504C Trip Out of Limits		DATE	TIME	
SYSTEM AFFECTED	PLANT STATUS AT TIME OF EVENT		TESTING	
500 RPS	MODE RUN PWR(MWT) 2515 LOAD(MWE) 813		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

DESCRIPTION OF EVENT

While performing surveillance DIS 500-7 switch 504C tripped above T.S. limit of 400# increasing (5# head correction and switch tripped at 402#). Second and subsequent trips were below T.S. limit but were above Dresden Station limit. Switch was adjusted within limits.

10 CFR50.72 NRC RED PHONE
NOTIFICATION MADE☐ YES ☒ NOEQUIPMENT FAILURE N/A
☐ YES ☒ NO WORK REQUEST NO.

RESPONSIBLE SUPERVISOR R. Thomas

DATE 6/28/82

PART 2 OPERATING ENGINEER'S COMMENTS

The switch was immediately recalibrated and repeatability verified.

<input type="checkbox"/> EVENT OF PUBLIC INTEREST	<input type="checkbox"/> 24-HOUR NRC NOTIFICATION REQ'D
<input type="checkbox"/> TECH. SPEC. VIOLATION	TELEPH Mike Jordan (courtesy) 6/29/82 1030
<input type="checkbox"/> NON REPORTABLE OCCURRENCE	REGION III DATE TIME
<input type="checkbox"/> 14 DAY REPORTABLE/T.S.	TELEGM/TELECOPY REGION III DATE TIME
<input checked="" type="checkbox"/> 30 DAY REPORTABLE/T.S. 6.6.3.2.a	<input type="checkbox"/> CECO CORPORATE NOTIFICATION MADE
<input type="checkbox"/> ANNUAL/SPECL REPORT REQ'D	IF ABOVE NOTIFICATION IS PER 10CFR21
A.I.R. #	<input type="checkbox"/> 5-DAY WRITTEN REPORT REQ'D PER 10CFR21
L.E.R. # 82-26/03L-0	TELEPH D. Galle 6/29/82 1245
	CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT
COMPLETED AND REVIEWED

Michael Wright

6/29/82

OPERATING ENGINEER

INVESTIGATED REPORT & RESOLUTION
ACCEPTED BY STATION REVIEWJ. Brunner
7/19/82Michael Wright
7-20-82RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTIONJ. Brunner
7/20/82
STATION SUPERINTENDENT7/20/82
DATE