

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 C T M N S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 3 6 7 0 6 1 7 8 2 8 0 7 1 5 8 2 9

DOCKET NUMBER 60 61 EVENT DATE 68 69 REPORT DATE 74 75

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During a containment entry for routine surveillance a leak was noticed in the safety

0 3 injection test header at two places upstream of relief valve 2-S1-466. There are no

0 4 probable consequences as a result of this event. Similar events: 81-022, 81-2, 80-27,

0 5 77-37, 77-10.

0 6

0 7

0 8

0 9

SYSTEM CODE S F 11 CAUSE CODE B 12 CAUSE SUBCODE A 13 COMPONENT CODE P I P E X X 14 COMP. SUBCODE A 15 VALVE SUBCODE Z 16

EVENT YEAR 8 2 SEQUENTIAL REPORT NO. 0 2 3 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

LER NO. REPORT NUMBER 17 ACTION TAKEN B 18 FUTURE ACTION F 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NFRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER B 1 3 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Pressure waves from cycling of relief valve 2-S1-466 causes abnormal stresses in the

1 1 safety injection test header. The cracks were weld repaired and the affected section

1 2 of pipe will be replaced at the next refuel outage. Further design changes are being

1 3 considered.

1 4

FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY RELEASED Z 33 CONTENT OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED N 44 DESCRIPTION NA 45

8207270083 820715
PDR ADDCK 05000336
S PDR

NRC USE ONLY

NAME OF PREPARED Steve Stadnick PHONE (203) 44-71791 Ext. 4427