


VERMONT YANKEE NUCLEAR POWER CORPORATION

Proposed Change No. 102



RD 5, Box 169, Ferry Road, Brattleboro, VT 05301

2.C.15.1
FVY 82-85

REPLY TO:

ENGINEERING OFFICE

1671 WORCESTER ROAD
FRAMINGHAM, MASSACHUSETTS 01701

TELEPHONE 617-872-8100

July 22, 1982

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation

References: (a) License No. DPR-28 (Docket No. 50-271)
(b) Letter, USNRC to VYNPC, dated April 22, 1982; Inspection
Report No. 50-271/82-03

Subject: Limiting Conditions for Operation - Standby Liquid Control
System

Dear Sir:

Pursuant to Section 50.59 of the Commissions Rules and Regulations,
Vermont Yankee Nuclear Power Corporation hereby proposes the following
modifications to Appendix A of the Operating License.

Proposed Change:

Replace page 80 using the attached page. This page discusses the
Limiting Conditions as relates to the operability of the Standby Liquid
Control System.

Reason & Bases for Change:

The current Technical Specifications do not clearly specify the actions
to be taken when the SLC tank concentration/volume limits are not met. In
accordance with the recommendations contained in Reference (b), this proposed
change is intended to clarify the LCO requirements as relates to SLC Tank
requirements, and specify what actions will be taken when those requirements
are not met. The requirements dealing with Tank Concentration/Temperature
have already been administratively applied to the station as a result of the
problems described in Reference (b).

Safety Considerations:

This proposed change is administrative in nature and is intended only to
clarify the actions that must be taken when certain parameters are not within
established limits.

This proposed change has been reviewed by the Vermont Yankee Nuclear
Safety Audit and Review Committee.

8207270372 820722
PDR ADOCK 05000271
P PDR

A001 Rec'd
w/out
Check

VERMONT YANKEE NUCLEAR POWER CORPORATION

United States Nuclear Regulatory Commission
Attention: Office of Nuclear Reactor Regulation

July 22, 1982
Page 2

Fee Determination:

This proposed change is pro forma, administrative in nature and has no safety or environmental significance. For these reasons, Vermont Yankee Nuclear Power Corporation proposes this change as a Class II Amendment and a payment of \$1,200.00 is enclosed.

Schedule of Change:

The proposed changes will be incorporated into the Technical Specifications as soon as practical following receipt of your approval.

We trust submittal is acceptable to you; however, should you have any questions, please contact us.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

Louis H Heider
Louis H. Heider
Vice President

COMMONWEALTH OF MASSACHUSETTS)
) ss
MIDDLESEX COUNTY)

Then personally appeared before me, Louis H. Heider, who, being duly sworn, did state that he is a Vice President of Vermont Yankee Nuclear Power Corporation, that he is duly authorized to execute and file the foregoing request in the name and on the behalf of Vermont Yankee Nuclear Power Corporation and that the statements therein are true to the best of his knowledge and belief.

J. B. Sinclair
J. B. Sinclair Notary Public
My Commission Expires June 1, 1984