

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	A	S	O	S	Z	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE							14	LICENSE NUMBER											25	LICENSE TYPE					30	57 CAT 58		

CON'T

0 1 7 8

REPORT SOURCE L 6 0 5 0 0 0 3 6 1 7 0 0 6 1 2 8 2 8 0 7 0 9 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While in Mode 3 the Electro-Hydraulic Valve 2HV4714 failed to open fully.

0 3 | This rendered the motor-driven AFW pump 2P-504 inoperable and reduced the number

0 4 | of operable trains to two from three. There was no consequence to the

0 5 | public health and safety due to the availability of the other two 100% flow

0 6 | trains, and in addition there is no decay heat in the core.

0 7 |

0 8 |

7 8 9

SYSTEM CODE 0 9		CAUSE CODE H H		CAUSE SUBCODE E		COMPONENT CODE I N S T R U						COMP. SUBCODE S		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
LER/RO REPORT NUMBER 17		EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 3 0		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN B		FUTURE ACTION Z	
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38
SHUTDOWN METHOD Z		HOURS 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER A		COMPONENT MANUFACTURER X 9 9 9		ACTION TAKEN B		FUTURE ACTION Z	
39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 1 The valve 2HV4/14 was not opening fully on a signal from the Control Room.

1 1 The cause was suspected to be the E/H operator. The valve was disassembled

1 2 and rebuilt. The exact cause was not determined. No other corrective action

1 3 was required.

1 4

7 8 9

7 8 9 10 11 12 13 44 45 46 47 48 49 50

FACILITY STATUS (1) 5 (2) B (28) % POWER (3) 0 (4) 0 (5) 0 (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (31) B DISCOVERY DESCRIPTION (32) Operator observation

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 Z 33 Z 34 NA
7 8 9 10 11 44
45 80

PERSONNEL EXPOSURES										DESCRIPTION									
NUMBER					TYPE														
1	7	0	0	37	Z	38	NA												
7	8	9	10	11	12	13													

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 NA

1		9		Z		42		43		DESCRIPTION		NA	
7	8	9	10										

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N 44 NA *me* NRC USE ONLY

8207270490 820709
PDR ADCK 05000361
S PDR

H. B. Ray

68 69 80

PHONE 714/492-7700