



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29055
(803) 345-4040

John L. Skolds
Vice President
Nuclear Operations

October 26, 1990
813.20

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:

SUBJECT: VIRGIL C. SUMMER STATION
DOCKET NO. 5C/395
OPERATING LICENSE NO. NPF-12
TECHNICAL SPECIFICATION CHANGE
REQUEST FOR REVISION TO 3/4.8.4

South Carolina Electric and Gas Company (SCE&G) hereby requests a revision to the Technical Specifications for the Virgil C. Summer Nuclear Station (VCSNS). The proposed change to Technical Specification 3/4.8.4, "Electrical Equipment Protective Devices," allows the deletion of two valves (XVG 8803 A and B-SI) from Table 3.8-2, the addition of twelve valves to Table 3.8-2, the rearrangement of Table 3.8-2 into alphanumeric order and the updating of ten valve designations. Valve functions listed on Table 3.8-2 will also be updated to agree with the site computer system listing. Surveillance test requirements will be added to those valves whose overloads are not bypassed to assure operability in accident conditions. Lastly, surveillance requirements for circuitry not used at VCSNS will be deleted.

The change request is contained in the following attachments:

- Attachment 1: The Technical Specification pages for 4.8.4.2 with requested changes indicated.
- Attachment 2: The Technical Specification pages for Table 3.8-2 with requested changes indicated.
- Attachment 3: A description of the amendment request and supporting safety evaluation.
- Attachment 4: A description of the amendment request and associated no significant hazards evaluation.


The proposed Technical Specification change has been reviewed and approved by the Plant Safety Review Committee and the Nuclear Safety Review Committee. SCE&G requests NRC review and approval of this Technical Specification change by March 1, 1991.

Document Control Desk
October 26, 1990
813.20
Page 2

I declare that the statements and matters set forth herein are true and correct to the best of my knowledge, information and belief.

Should you have any questions, please call at your convenience.

Very truly yours,



John L. Skolds

JDG:JLS:lcd
Attachments

c: O. W. Dixon, Jr./T. C. Nichols, Jr.
E. C. Roberts
R. V. Tanner
S. D. Ebnetter
G. F. Wunder
General Managers
NRC Resident Inspector
J. B. Knotts, Jr.
H. G. Shealy
J. D. Graham
NSRC
NPCF
RTS (TSP 870014)