

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of ) UNIT NO. 1  
                              ) Docket No. 50-334  
Duquesne Light Company ) License No. DPR-66  
Beaver Valley Power Station)

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A to these licenses be amended to reduce the required river water flow rate through the Recirculation Spray heat exchangers from 8,000 gpm to 6,000 gpm for the remainder of cycle eight (8) operation.

The proposed Technical Specification changes are set forth in Attachments A to this Application. A Safety Analysis and No Significant Hazard Evaluation are set forth in Attachment B. Typed replacement pages for the Technical Specifications are contained on Attachment C.

Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to these Operating Licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber  
J. D. Sieber  
Vice President, Nuclear

Subscribed and sworn to before me

on this 25th day of October, 1992

Sheila M. Fattor

Notary Public  
Sheila M. Fattor  
Shippingport Boro, Beaver County  
My Commission Expires Sept. 26, 1994  
Member, Pennsylvania Association of Notaries

2011030075 201025  
PDR ADOCK 05000334  
PDC