



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057-0191  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:  
(717) 948-8005

November 30, 1993  
C311-93-2141

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Subject: Three Mile Island Nuclear Generating Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Technical Specification Change Request (TSCR) No. 234  
Removal of Protective and Setpoint Limits from Technical  
Specifications to the Core Operating Limits Report

In accordance with 10 CFR 50.4(b)(1), enclosed is Technical Specification  
Change Request No. 234.

Also enclosed is the Certificate of Service for this request certifying  
service to the chief executives of the township and county in which the  
facility is located, as well as the designated official of the Commonwealth of  
Pennsylvania, Bureau of Radiation Protection.

The purpose of this TSCR is to request relocation of the protective and  
maximum allowable setpoint limits for axial power imbalance and the trip  
setpoint for nuclear overpower based on RCS flow (flux-to-flow) to the  
existing TMI-1 Core Operating Limits Report (COLR). The proposed change is in  
accordance with GL 88-16 guidance with regard to placing cycle-dependent  
parameters into the COLR and the NRC-approved Babcock and Wilcox Fuel Company  
(BWFC) Topical Report BAW-10179P-A, "Safety Criteria and Methodology for  
Acceptable Cycle Reload Analyses." The TMI-1 Cycle 10 COLR, submitted to the  
NRC on November 7, 1993 (C311-93-2140), includes these protective and maximum  
allowable setpoint limits and nuclear overpower trip setpoints to support this  
Technical Specifications change.


060103

9312080055 931130  
PDR ADOCK 05000289  
P PDR

*Flou*  
*11*

Pursuant to 10 CFR 50.51(a)(1), enclosed is our analysis, applying the standards in 10 CFR 50.92 to make a determination of no significant hazards considerations. As stated above, pursuant to 10 CFR 50.91(a), we have provided a copy of this letter, the proposed change in Technical Specifications, and our analyses of significant hazards considerations to Richard P. Janati, the designated representative of the Commonwealth of Pennsylvania.

Sincerely,



T. G. Broughton  
Vice President and Director, TMI-1

DJD/amc

Enclosures: (1) Technical Specification Change Request No. 234  
(2) Certificate of Service for Technical Specification Change Request No. 234

cc: Administrator, Region I  
TMI Senior Resident Inspector  
TMI-1 Senior Project Manager