

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

08 | \_\_\_\_\_

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

PHONE: 815-942-2920, ext. 421



Commonwealth Edison

## DEVIATION REPORT

DVR NO. 12 - 2 - 82 - 40  
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION

Loss of D/W to Torus 1 psid

OCCURRED

6/29/82 1015

DATE TIME

SYSTEM AFFECTED

1600

PLANT STATUS AT TIME OF EVENT

Containment Systems

MODE RUN

PWR(MWT)

2341

LOAD(MWE)

758

TESTING

☒ YES ☐ NO

DESCRIPTION OF EVENT

While performing DIS 2300-3, when HPCI steam supply isolation valve MO 2301-4

was auto closed, the drywell pressure dropped about .15 psid in a few minutes. After reopening the valve, pressure increased very rapidly. The drywell differential pressure was reestablished. The valve MO-2301-4 was electrically backseated open and caution carded to stop steam leakage to drywell.

10 CFR50.72 NRC RED PHONE

☐ YES ☒ NO

NOTIFICATION MADE

YES NO

EQUIPMENT FAILURE

D 21340

☒ YES☐ NO

WORK REQUEST NO.

RESPONSIBLE SUPERVISOR

J. R. Doxsey

DATE 6/29/82

PART 2 OPERATING ENGINEER'S COMMENTS

Drywell to torus delta was at 0.94 psid at 1015 and was restored to 1.01 psid at 1035.

☐ EVENT OF PUBLIC INTEREST☐ TECH. SPEC. VIOLATION☐ NON REPORTABLE OCCURRENCE☐ 14 DAY REPORTABLE/T.S.☒ 30 DAY REPORTABLE/T.S. 6.6.B.2.b.☐ ANNUAL/SPECL REPORT REQ'D☐ 24-HOUR NRC NOTIFICATION REQ'D

TELEPH

REGION III

DATE

TIME

TELEGM/TELECOPY

REGION III

DATE

TIME

☐ CECO CORPORATE NOTIFICATION MADE

IF ABOVE NOTIFICATION IS PER 10CFR21

☐ 5-DAY WRITTEN REPORT REQ'D PER 10CFR21

A.T.R. #

L.E.R. # 82-24/03L-0

TELEPH

F. A. Palmer

CECO CORPORATE OFFICER

6/30/82

1426

DATE

TIME

PRELIMINARY REPORT  
COMPLETED AND REVIEWED

John M. Almer

OPERATING ENGINEER

6/30/82

DATE

INVESTIGATED REPORT & RESOLUTION  
ACCEPTED BY STATION REVIEW

J A. Ciesla 7/23/82

John M. Almer  
7/26/82RESOLUTION APPROVED AND  
AUTHORIZED FOR DISTRIBUTIONE. M. Pagan  
STATION SUPERINTENDENT7/26/82  
DATE