



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

November 15, 1990
C311-90-2144

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Errata of GPU Nuclear's Inservice Inspection (ISI)
Data Report, dated June 4, 1990

During a recent internal audit, GPU Nuclear discovered an error in the NIS-1 Inservice Inspection (ISI) Data Report which was submitted to the NRC on June 4, 1990. Attached is the revised page 16 from Table 1 of the report. The correction, indicated by a margin bar, reports Reactor Coolant Pump "D" main flange bolt RCPd-005MF-F obstructed instead of RCPd-003MF-F as previously reported.

Sincerely,

H. D. Hukill
Vice President and
Director, TMI-1

HDH/MRK
Attachment

cc: Region I Administrator, NRC
Director, Project Directorate I/4, NRC
TMI-1 Senior Resident Inspector, NRC
TMI-1 Project Manager, NRC
Chief Inspector, PA DOLI Boiler Division
Hartford Steam Boiler I&I Co.

9011270134 901115
PDR ADOCK 05000289
PDC

AOA7
11