

As required by the Provisions of the ASME Code Rules

7. Components Inspected See Table 1 *Revision 1 - See attached change to page 16

[illegible]

9011270144 9011115
PDR ADOCK 05000289
Q PDC

NIS-1 OWNERS DATA REPORT FOR INSERVICE INSPECTION

1. OWNER: Metropolitan Edison Company, 2800 Potomac Pike, Reading, Pennsylvania
2. PLANT: Three Mile Island Nuclear Generating Station, Route 441 South, Middletown, Pennsylvania
3. PLANT UNIT: 1
4. OWNER CERTIFICATION OF AUTHORIZATION (if required): None
5. COMMERCIAL SERVICE DATE: 09/02/74
6. NATIONAL BOARD NUMBER FOR UNIT: Reactor Vessel N-109

OUTAGE BR
TABLE 1

| ASME CAT | ASME ITEM NO | SYSTEM / COMPONENT | COMPONENT ID | DESCRIPTION | NDE METH | MAT | DIA | REMARKS |
|-------------|-----------------|--------------------------------------|--------------|-------------|-------------|-------|-----|------------------------------------|
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-017MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-018MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-019MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-020MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-021MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-022MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-023MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1C | RCPc-024MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-001MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-002MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-003MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-004MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. Obstruction. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-005MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. Obstruction. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-006MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-007MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-008MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-009MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-010MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-011MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |
| B-G-1 | B5.3 | RC /Reactor Coolant Pump - RC-P1D | RCPd-012MF-F | Bolting | VT | CS/SS | 4.5 | Examined in place. |