NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N C B E P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 3 2 5 (7) | 0 7 0 2 8 2 (8) | 0 7 3 0 8 2 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During plant operation, while running 1D RHR service water pump for suppression
03 pool cooling, the pump tripped. An immediate check of RTGB instrumentation and the
04 pump motor power supply breaker target indications did not reveal any irregularities.
05 At the time, the remaining RHR service water pumps were operable and 1B pump was
06 utilized for suppression pool cooling. This event did not affect the health and
07 safety of the public.
08 Technical Specifications 3.6.2.2, 3.7.1.1
7 8 9 80

09 SYSTEM CODE C F (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER [EVENT YEAR 8 2 (21 22) | — (23) | SEQUENTIAL REPORT NO. 0 7 9 (24 26) | / (27) | OCCURRENCE CODE 0 3 (28 29) | REPORT TYPE L (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN X (18) (33) | FUTURE ACTION X (19) (34) | EFFECT ON PLANT Z (20) (35) | SHUTDOWN METHOD Z (21) (36) | HOURS (22) 0 0 0 0 (37 40) | ATTACHMENT SUBMITTED N (23) (41) | NPRD-4 FORM SUB. Y (24) (42) | PRIME COMP. SUPPLIER A (25) (43) | COMPONENT MANUFACTURER Z 9 9 9 (26) (44 47)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of this event could not be determined. Troubleshooting of the pump motor
11 power supply electrical protective devices and a vibration and temperature check of
12 the pump while running did not reveal any irregularities relating to this event.
13 Following the satisfactory completion of an operability test, the pump was returned to
14 service.
7 8 9 80

15 FACILITY STATUS E (28) (9) | % POWER 0 8 0 (29) (10 12) | OTHER STATUS (30) NA (13 44) | METHOD OF DISCOVERY A (31) (45) | DISCOVERY DESCRIPTION (32) Operational Event (46 80)
7 8

16 ACTIVITY RELEASED Z (33) (9) | CONTENT OF RELEASE Z (34) (10) | AMOUNT OF ACTIVITY (35) NA (11 44) | LOCATION OF RELEASE (36) NA (45 80)
7 8

17 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) (9 11) | TYPE Z (38) (12) | DESCRIPTION (39) NA (13 80)
7 8

18 PERSONNEL INJURIES NUMBER 0 0 0 (40) (9 11) | DESCRIPTION (41) NA (12 80)
7 8

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) (9) | DESCRIPTION (43) NA (10 80)
7 8

20 PUBLICITY ISSUED N (44) (9) | DESCRIPTION (45) NA (10 68) | NRC USE ONLY (69 80)
7 8

8208090202 820730
PDR ADOCK 05000325
S PDR

NAME OF PREPARER M. J. PASTVA, JR. PHONE: 919-457-9521

GPO 917-926