



**Commonwealth Edison**


Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

July 21, 1982

DJS LTR: #82/806

James G. Keppler, Regional Administrator  
Directorate of Regulatory Operations Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reportable Occurrence Report #82-25/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.

  
D. J. Scott  
Station Superintendent  
Dresden Nuclear Power Station

DJS:mb

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
U. S. NRC, Document Management Branch  
File/NRC



Commonwealth Edison

## DEVIATION REPORT

DVR NO.

12  
STA2  
UNTT82  
YEAR41  
NO.

PART 1

TITLE OF DEVIATION

LPCI Suction Valve (M02-1501-5D) Failure To Open

OCCURRED

7/1/82

1915

DATE

TIME

SYSTEM AFFECTED

1500

PLANT STATUS AT TIME OF EVENT

LPCI

MODE RUN

PWR(MWT)

2330

LOAD(MWE)

761

TESTING

☒ YES☐ NO

DESCRIPTION OF EVENT

During LPCI Valve Operability Testing, LPCI suction valve M02-1501-5D failed to reopen following closure. Breaker racked out and racked back in. Valve manually moved off seat and electrically would still not open. Manually reopened suction valve and EM's notified to investigate.

10 CFR50.72 NRC RED PHONE

☐ YES☒ NO

NOTIFICATION MADE

YES

NO

EQUIPMENT FAILURE

D21387

☒ YES☐ NO

WORK REQUEST NO.

RESPONSIBLE SUPERVISOR

Bob Herbert

DATE

7/1/82

PART 2

OPERATING ENGINEER'S COMMENTS

Electricians cleaned aux. contacts in breaker, and valve operated properly.

☐ EVENT OF PUBLIC INTEREST☐ TECH. SPEC. VIOLATION☐ NON REPORTABLE OCCURRENCE☐ 14 DAY REPORTABLE/T.S.☒ 30 DAY REPORTABLE/T.S. 6.6.B.2.b.☐ ANNUAL/SPECL REPORT REQ'D☐ 24-HOUR NRC NOTIFICATION REQ'D

TELEPH

N/A

REGION III

DATE

TIME

TELEGM/TELECOPY

N/A

REGION III

DATE

TIME

☐ CECO CORPORATE NOTIFICATION MADE

IF ABOVE NOTIFICATION IS PER 10CFR21

☐ 5-DAY WRITTEN REPORT REQ'D PER 10CFR21

A.I.R. #

L.E.R. # 82-25/03L-0

TELEPH

F. A. Palmer

CECO CORPORATE OFFICER

7/2/82

DATE

1543

TIME

PRELIMINARY REPORT

COMPLETED AND REVIEWED

John M. Almer

OPERATING ENGINEER

7/2/82

DATE

INVESTIGATED REPORT & RESOLUTION  
ACCEPTED BY STATION REVIEWRESOLUTION APPROVED AND  
AUTHORIZED FOR DISTRIBUTION

STATION SUPERINTENDENT

DATE