

## INTERIM CHANGE REQUEST

Plan Title/Rev. Unit 1 ISI Plan Rev 2ICR No. ISI-IR2-005Reference: Page Sections 4.1 and 4.2  
Table  
Relief Request, and/or  
Component:

pg 1 of 29

Reason for Change: IRFO3 outage activities have identified the need to reschedule certain exam items. This rescheduling maintains the required outage and period exam percentages within the margins allowed by ASME XI.

## Proposed Revision:

- Replace the existing section 4.0, 4.1 and 4.2 pages numbered 4, 9, 11, 16, 17, 19, 24, 25, 26, 31, 32, 140, 145, 147, 194, 190, 191, 261, 262, 265 and 266. <sup>39, 54</sup> with the attached revised pages.
- Add pages 54.1, 93.1, 96.1, 96.2
- Replace the existing Appendix B page 3 with the attached updated Appendix B page 3.

C. DeBonis  
Initiator

EMCA  
Department

11.19.93  
Date

Approved: ☒ Yes ☐ No

R. B. May  
Codes and Standards Supervisor

11.19.93  
Date

Reason for Disapproval:

This subsection describes the examination areas and NDE methods for the Class 1 pressure retaining components and associated component integral welded attachments as specified in Article IWB of the Code. For pressure testing, see Section 5.

Class 1 valve bodies exceeding 4 NPS have been grouped according to size, constructional design, manufacturing method and function in accordance with Table IWB-2500-1, category B-M-2, Note 3 of the Code. These groups are delineated below. One valve from each group has been selected for examination as denoted by the asterisk "\*".

Group 1 - 6" Forged Pressurizer Relief Valves

1-8010A \*  
1-8010B  
1-8010C

Group 2 - 12" Forged Gate Valves Isolating the RC System from the RHR System

1-8701A \*  
1-8701B  
1-8702A  
1-8702B

Group 3 - 10" Forged Check Valves Isolating the RC System from the SI System

1-8948A  
1-8948B  
1-8948C  
1-8948D  
1-8956A  
1-8956B  
1-8956C \*  
1-8956D

Group 4 - 6" Forged Check Valves Isolating the RC System from the SI System

1-8818A  
1-8818B  
1-8818C  
1-8818D  
1-8949A  
1-8949B \*  
1-8949C  
1-8949D  
1-8841A  
1-8841B

ICR-5

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
	ASME SEC. XI CATGY NDE ITEM NO METH		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
			1 2 3	1 2 3	1 2 3		

REACTOR COOLANT TBX-RCPCRV-01

005400	TBX-1-1400-1 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005420	TBX-1-1400-2 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005440	TBX-1-1400-3 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005460	TBX-1-1400-4 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005480	TBX-1-1400-5 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005500	TBX-1-1400-6 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**
005520	TBX-1-1400-7 RV STUD	B-G-1 B6.30	UT MT	1 - - X	- - -	- - -	82	TDLR VERIFICATION BOUNDARY.  **TBX-25**

ICR-5

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

ICR 151-1R2-005  
Pg 4 of 29

PAGE: 11

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI CATGY WDE ITEM NO METH	PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
		1 2 3	1 2 3	1 2 3		

REACTOR COOLANT TBX-RCPCRV-01

005680 TBX-1-1400-15 B-G-1 UT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

005700 TBX-1-1400-16 B-G-1 UT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

005720 TBX-1-1400-17 B-G-1 UT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT



\*\*TBX-25\*\*

005740 TBX-1-1400-18 B-G-1 UT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT



\*\*TBX-25\*\*

ICR-5

005760 TBX-1-1400-19 B-G-1 UT 1 - - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

005780 TBX-1-1400-20 B-G-1 UT 1 - - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

005800 TBX-1-1400-21 B-G-1 UT 1 - - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

ICR 151-1A2-005

pg 5 of 29

PAGE: 16

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR	
					FIRST PERIOD			SECOND PERIOD			THIRD PERIOD				
ASPE															
SEC. XI															
SUMMARY EXAMINATION AREA		CATGY	NDE		O U T A G E									INSTRUCTIONS	
NUMBER IDENTIFICATION		ITEM NO	METH		1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**	

REACTOR COOLANT TBX-RCPCRV-01

006380 TBX-1-1400-50 B-G-1 UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

006400 TBX-1-1400-51 B-G-1 UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

006420 TBX-1-1400-52 B-G-1 UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

006440 TBX-1-1400-53 B-G-1 UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

006460 TBX-1-1400-54 B-G-1 UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV STUD B6.30 MT

\*\*TBX-25\*\*

ICR-5

006600 TBX-1-1400-1 B-G-1 MT 1 - - X - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006620 TBX-1-1400-2 B-G-1 MT 1 - - X - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

p86 of 29

		INSPECTION INTERVAL		PLAN STATUS						PRESERVICE YEAR			
				FIRST		SECOND		THIRD					
		ASME		PERIOD		PERIOD		PERIOD					
		SEC. XI		-----		-----		-----					
SUMMARY EXAMINATION AREA		CATGY NDE		- - - - - O U T A G E - - - - -						INSTRUCTIONS			
NUMBER	IDENTIFICATION	ITEM NO METH		1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**

REACTOR COOLANT TBX-RCPCRV-01

006640 TBX-1-1400-3 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006660 TBX-1-1400-4 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006680 TBX-1-1400-5 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006700 TBX-1-1400-6 S1 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006720 TBX-1-1400-7 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006740 TBX-1-1400-8 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

006760 TBX-1-1400-9 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV NUT B6.10

ICR-5

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

Pg 7 of 29

PAGE: 19

		INSPECTION INTERVAL		PLAN STATUS									PRESERVICE YEAR		
		ASPE		FIRST PERIOD			SECOND PERIOD			THIRD PERIOD					
		SEC. XI													
SUMMARY EXAMINATION AREA		CATGY NDE		- - - - - O U T A G E - - - - -									INSTRUCTIONS		
NUMBER	IDENTIFICATION	ITEM NO METH		1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**		
<u>REACTOR COOLANT TBX-RCPCRV-01</u>															
006920	TBX-1-1400-17 RV NUT	B-G-1 B6.10	NT	1	-	(X)	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.	
006940	TBX-1-1400-18 RV NUT	B-G-1 B6.10	NT	1	-	(X)	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.	
006960	TBX-1-1400-19 RV NUT	B-G-1 B6.10	NT	1	-	-	X	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.	
006980	TBX-1-1400-20 RV NUT	B-G-1 B6.10	NT	1	-	-	X	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.	
007000	TBX-1-1400-21 RV NUT	B-G-1 B6.10	NT	1	-	-	X	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.	
007020	TBX-1-1400-22 RV NUT	B-G-1 B6.10	NT	1	-	-	X	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.	
007040	TBX-1-1400-23 RV NUT	B-G-1 B6.10	NT	1	-	-	X	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.	

ICR-5

ICR 151-1R2-005  
pg 8 of 29

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

PAGE: 24

		INSPECTION INTERVAL		PLAN STATUS									PRESERVICE YEAR
				FIRST PERIOD			SECOND PERIOD			THIRD PERIOD			
		ASME											
		SEC. XI		-----			-----			-----			
SUMMARY EXAMINATION AREA		CATGY	NDE	- - - - - O U T A G E - - - - -									INSTRUCTIONS
NUMBER	IDENTIFICATION	ITEM NO	METH	1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**

REACTOR COOLANT TBX-RCPCRV-01

007620 TBX-1-1400-52 B-G-1 WT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV MUT B6.10

007640 TBX-1-1400-53 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV MUT B6.10

007660 TBX-1-1400-54 B-G-1 MT 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV MUT B6.10

007800 TBX-1-1400-1 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007820 TBX-1-1400-2 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007840 TBX-1-1400-3 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007860 TBX-1-1400-4 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

ICR-5



DATE: 03/22/93

CONANACHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

ICR 151-1R2-005  
pg 9 of 29

PAGE: 25

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATGY NDE ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
					FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
		1	2	3	1	2	3		

REACTOR COOLANT TBX-RCPCRV-01

007880 TBX-1-1400-5 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007900 TBX-1-1400-6 S1 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

ICR-5

007920 TBX-1-1400-7 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007940 TBX-1-1400-8 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007960 TBX-1-1400-9 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

007980 TBX-1-1400-10 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008000 TBX-1-1400-11 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

PAGE: 26

INSPECTION INTERVAL		PLAN STATUS									PRESERVICE YEAR		
		FIRST			SECOND			THIRD					
ASME		PERIOD			PERIOD			PERIOD					
SEC. XI		-----											
SUMMARY EXAMINATION AREA		CATGY	NDE	- - - - - O U T A G E - - - - -									INSTRUCTIONS
NUMBER	IDENTIFICATION	ITEM NO	METH	1	2	3	1	2	3	1	2	3	**CALIBRATION: BLOCK**

REACTOR COOLANT TBX-RCPCRV-01

008020 TBX-1-1400-12 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008040 TBX-1-1400-13 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008060 TBX-1-1400-14 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008080 TBX-1-1400-15 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008100 TBX-1-1400-16 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008120 TBX-1-1400-17 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

008140 TBX-1-1400-18 B-G-1 VT-1 1 - - X - - - - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

ICR 151-1R2-005

Pg 11 of 29

PAGE: 31

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR	
					FIRST			SECOND			THIRD				
		ASME			PERIOD			PERIOD			PERIOD				
		SEC. XI			-----			-----			-----				
SUMMARY EXAMINATION AREA		CATGY NDE			- - - - - O U T A G E - - - - -									INSTRUCTIONS	
NUMBER IDENTIFICATION		ITEM NO METH			1 2 3			1 2 3			1 2 3			**CALIBRATION BLOCK**	
-----		-----			-----			-----			-----			-----	

REACTOR COOLANT TBX-RCPCRV-01

008720	TBX-1-1400-47 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008740	TBX-1-1400-48 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008760	TBX-1-1400-49 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008780	TBX-1-1400-50 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008800	TBX-1-1400-51 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008820	TBX-1-1400-52 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											
008840	TBX-1-1400-53 RV WASHER	B-G-1 VT-1	1	-	-	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
		B6.50											

ICR-5

DATE: 03/22/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

ICR 151-102-005

Pg 12 of 29 PAGE: 32

		INSPECTION INTERVAL	PLAN STATUS									PRESERVICE YEAR
			FIRST PERIOD			SECOND PERIOD			THIRD PERIOD			
ASME												
SEC. XI			-----			-----			-----			
SUMMARY EXAMINATION AREA		CATGY MDE	- - - - - O U T A S E - - - - -									INSTRUCTIONS
NUMBER IDENTIFICATION		ITEM NO METH	1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**

REACTOR COOLANT TBX-RCPCRV-01

008860 TBX-1-1400-54 B-G-1 VT-1 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
RV WASHER B6.50



ICR-5

REACTOR COOLANT TBX-RCPCPR-01

009000 TBX-1-2100-1 B-B UT 1 - - - - - X - - 79 TDLR VERIFICATION BOUNDARY.  
PRESSURIZER LOWER HEAD TO B2.11  
SHELL WELD  
R161A \*\*TBX-1\*\*

009100 TBX-1-2100-5 B-B UT 1 C - - - - - - - - 79 TDLR VERIFICATION BOUNDARY.  
PRESSURIZER UPPER HEAD TO B2.11  
SHELL WELD  
R161A \*\*TBX-1\*\*

009200 TBX-1-2100-6 B-B UT 1 - - - - - X - - 79 TDLR VERIFICATION BOUNDARY.  
PRESSURIZER LONG. WELD (1FT B2.12  
ADJ. WELD 1)  
R161A \*\*TBX-1\*\*

009300 TBX-1-2100-9 B-B UT 1 C - - - - - - - - 79 TDLR VERIFICATION BOUNDARY.  
PRESSURIZER LONG. WELD (1FT B2.12  
ADJ. WELD 5)  
R161A \*\*TBX-1\*\*

009400 TBX-1-2100-10 B-H UT 1 - - - - - X - - 82 TDLR VERIFICATION BOUNDARY.  
PRESSURIZER SUPPORT SKIRT WELD B2.20  
R161A \*\*TBX-40\*\*

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL	ASME SEC. XI CATGY NDE ITEM NO METH	PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
			1 2 3	1 2 3	1 2 3		

RESIDUAL HEAT REMOVAL 12-RH-1-001-2501R-1

015200 TBX-1-4101-9 B-J UT 1 - - - - - X - - - 82  
PIPE TO ELBOW B9.11 PT  
R154 817RB

\*\*TBX-12\*\*

015300 TBX-1-4101-10 B-J UT 1 - - - - - X - - - 82  
ELBOW TO PIPE B9.11 PT  
R154 817RB

\*\*TBX-12\*\*

015400 TBX-1-4101-11 B-J UT 1 - - - - - X - - - 82  
PIPE TO ELBOW B9.11 PT  
R154 817RB

\*\*TBX-12\*\*

015800 TBX-1-4101-8701A B-G-2 VT-1 1 - - X - - - - - 84  
VALVE BODY BOLTING B7.70  
R154 817RB

015810 TBX-1-4101-8701A B-M-2 VT-3 1 - - (X) - - - - - X - - - 84  
VALVE BODY INTERNAL SURFACES B12.50  
R154 817RB

GROUP 2 - ONE VALVE WITHIN THE  
GROUP TO BE EXAMINEDREACTOR COOLANT 10-RC-1-021-2501R-1

016100 TBX-1-4102-3 B-J UT 1 C - - - - - - - - 82  
PIPE TO ELBOW B9.11 PT  
A23 831RB

\*\*TBX-9\*\*

ICR-5

		INSPECTION INTERVAL	PLAN STATUS									PRESERVICE YEAR
			FIRST PERIOD			SECOND PERIOD			THIRD PERIOD			
ASME												
SEC. XI			-----			-----			-----			
SUMMARY EXAMINATION AREA		CATGY	O U T A G E									INSTRUCTIONS
NUMBER IDENTIFICATION		NDE										
		ITEM NO	1 2 3			1 2 3			1 2 3			**CALIBRATION BLOCK**

REACTOR COOLANT 10-RC-1-055-2501R-1

045900 TBX-1-4301-4 B-J UT 1 - - - X - - - 82  
ELBOW TO PIPE B9.11 PT  
A27 832RB

\*\*TBX-9\*\*

SAFETY INJECTION 10-SI-1-181-2501R-1

046700 TBX-1-4301-12 B-J UT 1 - - - - - X 82  
TEE TO PIPE B9.11 PT  
A27 829RB

\*\*TBX-9\*\*

046800 TBX-1-4301-13 B-J UT 1 - - - - - X 82  
PIPE TO ELBOW B9.11 PT  
A27 823RB

\*\*TBX-9\*\*

047000 TBX-1-4301-15 B-J UT 1 - - - - - X 82  
PIPE TO VALVE B9.11 PT  
A27 823RB

\*\*TBX-9\*\*

047100 TBX-1-4301-09486 B-J VT 1 1 - - - - - 84  
VALVE BODY BOLTING B7.70  
A27 831RB

DELETE

047150 TBX-1-4301-09486 B-J VT 3 1 - - - - - 84 GROUP 3 - ONE VALVE WITHIN THE  
VALVE BODY INTERNAL SURFACES B12.50  
A27 831RB

DELETE

GROUP TO BE EXAMINED

SAFETY INJECTION 6-SI-1-330-2501R-1

047300 TBX-1-4302-1 B-J UT 1 - - - X - - - 82  
VALVE TO PIPE B9.11 PT  
R154 816RB

\*\*TBX-5\*\*

ICR-5

DATE: 11/16/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 1 SCHED/COMPL COMPONENTS

pg 15 of 29

PAGE:

54.1

INSPECTION INTERVAL		PLAN STATUS			PRESERVICE YEAR
		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
ASME					
SEC. XI					
CATGY NDE		- - - - - O U T A G E - - - - -			INSTRUCTIONS
ITEM NO METH		1 2 3	1 2 3	1 2 3	**CALIBRATION BLOCK**
SUMMARY EXAMINATION AREA					
NUMBER IDENTIFICATION					

SAFETY INJECTION 10-SI-1-181-2501R-1

047200 TBX-1-4301-8956C B-G-2 VT-1 1 - - - - - X - - 84  
VALVE BODY BOLTING 87.70  
A27 823RB

ADD

047210 TBX-1-4301-8956C B-M-2 VT-3 1 - - X - - - - - 84 GROUP 3 - ONE VALVE WITHIN THE  
VALVE BODY INTERNAL SURFACES 812.50 GROUP TO BE EXAMINED  
A27 823RB

ICR-5

DATE: 11/17/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 2 ALL STATUS COMPONENTS

ICR 151-1K2-003

pg 16 of 29

PAGE:

93.1

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR		
					FIRST			SECOND			THIRD					
					PERIOD			PERIOD			PERIOD					
		ASME														
		SEC. XI			-----			-----			-----					
SUMMARY EXAMINATION AREA		CATGY WDE			- - - - - O U T A G E - - - - -									INSTRUCTIONS		
NUMBER IDENTIFICATION		IYEM NO METH			1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**		

MAIN STEAM 32-MS-1-004-1303-2

160450 TBX-2-2400-17L C-F-2 UT 1 - - C - - - - - 82 TDLR VERIFICATION BOUNDARY.  
LONG SEAM (2.5T ADJ. WELD 17) C5.52 MT  
R155AB77RB

ADD

\*\*TBX-33\*\*

ICR-5



DATE: 11/17/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 2 ALL STATUS COMPONENTS

pg 17 of 29

PAGE:

96.1

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL	ASME SEC. XI CATGY MDE ITEM NO METH	PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS
			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
			1 2 3	1 2 3	1 2 3		**CALIBRATION BLOCK**

RESIDUAL HEAT REMOVAL 12-RH-1-003-601R-2

174140 TBX-2-2500-7L C-F-1 UT 1 - - C - - - - - NA  
LONG SEAM (2.5T ADJ. WELD 7) C5.12 PT  
R77S B17SB

ADD

\*\*TBX-11\*\*

ICR-5

DATE: 11/17/93

COMANCHE PEAK UNIT 1  
INSERVICE INSPECTION LONG TERM PLAN  
CLASS 2 ALL STATUS COMPONENTS

pg 18 of 29

PAGE:

96.2

INSPECTION INTERVAL		PLAN STATUS			PRESERVICE YEAR
		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
ASME					
SEC. XI					
CATGY NDE		OUTAGE			INSTRUCTIONS
ITEM NO METH		1 2 3	1 2 3	1 2 3	**CALIBRATION BLOCK**
SUMMARY EXAMINATION AREA					
NUMBER IDENTIFICATION					

RESIDUAL HEAT REMOVAL 12-RH-1-003-601R-2

174250 TBX-2-2500-8L C-F-1 UT 1 - - C - - - - - NA  
LONG SEAM (2.5T ADJ. WELD 8) C5.12 PT  
R77S 816SB

ADD

\*\*TBX-11\*\*

ICR-5

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR	
		ASME			FIRST PERIOD			SECOND PERIOD			THIRD PERIOD				
SEC. XI		-----			-----			-----			-----				
SUMMARY EXAMINATION AREA		CATGY		NDE	O U T A G E									INSTRUCTIONS	
NUMBER IDENTIFICATION		ITEM NO		METH	1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**	

REACTOR COOLANT 4-RC-1-018-2501R-1

659700 TBX-1-4504-H21  
RC-1-018-055-C61A  
R30 B83RB

F-B  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA ANCHOR

ICR-5

659750 TBX-1-4504-H21  
RC-1-018-055-C61A  
R30 B83RB

B-K-1  
B10.10

PT

1 - - - - - X - - - - -

NA 5/8" 360 SADDLE.

REACTOR COOLANT 2-RC-1-035-2501R-1

659800 TBX-1-4206-H4  
RC-1-035-700-C41R  
R25 B13RB

F-B  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA BOX

659900 TBX-1-4206-H1  
RC-1-035-703-C41K  
R25 B14RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA SPRING

660000 TBX-1-4206-H2  
RC-1-035-703-C41K  
R25 B14RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA SHUBBER

660100 TBX-1-4206-H3  
RC-1-035-704-C41R  
R25 B13RB

F-B  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA BOX

REACTOR COOLANT 3-RC-1-052-2501R-1

660200 TBX-1-4304-H3  
RC-1-052-001-C41S  
R27 B14RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - - - -

NA SPRING

		INSPECTION INTERVAL		PLAN STATUS									PRESERVICE YEAR	
				FIRST PERIOD			SECOND PERIOD			THIRD PERIOD				
		ASME												
		SEC. XI		-----			-----			-----				
SUMMARY EXAMINATION AREA		CATGY MDC		- - - - - O U T A G E - - - - -									INSTRUCTIONS	
NUMBER IDENTIFICATION		ITEM NO METH		1 2 3			1 2 3			1 2 3			**CALIBRATION BLOCK**	
-----		-----		-----			-----			-----			-----	

REACTOR COOLANT 4-RC-1-075-2501R-1

663000	TBX-1-4503-H17 RC-1-075-004-C61R R30 882RB	F-C VT-3	1	-	-	X	-	-	-	-	-	NA	STRUT
		NOTE 1											
663100	TBX-1-4503-H13 RC-1-075-006-C61S R30 863RB	F-C VT-3	1	-	-	X	-	-	-	-	-	NA	SPRING
		NOTE 1											
663150	TBX-1-4503-H13 RC-1-075-006-C61S R30 863RB	B-K-1 PT	1	-	-	-	-	-	-	X	-	NA	4-1" LUGS.
		NOTE 1											
663200	TBX-1-4503-H20 RC-1-075-018-C81R R16 905RB	F-C VT-3	1	-	C	-	-	-	-	-	-	NA	STRUT
		NOTE 1											
663400	TBX-1-4503-H14 RC-1-075-027-C61R R30 873RB	F-C VT-3	1	-	-	X	-	-	-	-	-	NA	STRUT
		NOTE 1											
663500	TBX-1-4503-H10 RC-1-075-029-C51R R30 857RB	F-B VT-3	1	-	-	X	-	-	-	-	-	NA	BOX
		NOTE 1											
663600	TBX-1-4503-H8 RC-1-075-031-C51K R30 848RB	F-C VT-3	1	-	-	X	-	-	-	-	-	NA	SNUBBER
		NOTE 1											

ICR-5

pg 21 of 29

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR		
					FIRST			SECOND			THIRD					
		ASME			PERIOD			PERIOD			PERIOD					
		SEC. XI			-----			-----			-----					
SUMMARY EXAMINATION AREA		CATGY NDE			- - - - - O U T A G E - - - - -									INSTRUCTIONS		
NUMBER IDENTIFICATION		ITEM NO METH			1 2 3			1 2 3			1 2 3			**CALIBRATION BLOCK**		
-----		-----			-----			-----			-----			-----		

REACTOR COOLANT 4-RC-1-075-2501R-1

664400	TBX-1-4503-H11 RC-1-075-047-C51R R30 B58RB	F-C	VT-3	1	-	-	X	-	-	-	-	-	NA	STRUT
		NOTE 1												
664500	TBX-1-4503-H7 RC-1-075-048-C51K R30 B46RB	F-C	VT-3	1	-	-	X	-	-	-	-	-	NA	SHUBBER
		NOTE 1												
664800	TBX-1-4503-H4 RC-1-075-051-C51K R30 B46RB	F-C	VT-3	1	-	-	X	-	-	-	-	-	NA	SHUBBER
		NOTE 1												
664900	TBX-1-4503-H19 RC-1-075-052-C61K R16 B85RB	F-C	VT-3	1	-	C	-	-	-	-	-	-	NA	SHUBBER
		NOTE 1												
665000	TBX-1-4503-H18 RC-1-075-053-C61R R16 B84RB	F-C	VT-3	1	-	C	-	-	-	-	-	-	NA	STRUT
		NOTE 1												
665100	TBX-1-4503-H16 RC-1-075-054-C61R R30 B82RB	F-C	VT-3	1	-	-	X	-	-	-	-	-	NA	STRUT
		NOTE 1												
665200	TBX-1-4503-H15 RC-1-075-056-C61A R30 B82RB	F-B	VT-3	1	-	-	X	-	-	-	-	-	NA	ANCHOR
		NOTE 1												



ICR-5

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL	PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
	ASME SEC. XI					
	CATGY MDE	- - - - - O U T A G E - - - - -				
	ITEM NO METH	1 2 3	1 2 3	1 2 3		

REACTOR COOLANT TBX-RCPCSG-02

690200	TBX-RCPCSG-02-U1 A26 B59RB	F-B NOTE 1	VT-3	1 - - - - - X -	NA	S.G. UPPER LATERAL SUPPORT. 1457F34, US-1, TDLR VERIFICATION BOUNDARY.
690220	TBX-RCPCSG-02-U2 A26 B59RB	F-B NOTE 1	VT-3	1 - - - - - X -	NA	S.G. UPPER LATERAL SUPPORT. 1457F34, US-2, TDLR VERIFICATION BOUNDARY.
690240	TBX-RCPCSG-02-U3 A26 B59RB	F-B NOTE 1	VT-3	1 - - - - - X -	NA	S.G. UPPER LATERAL SUPPORT. 1457F35, RING, TDLR VERIFICATION BOUNDARY.
690280	TBX-RCPCSG-02-SM1 A26 B59RB	F-C NOTE 1	VT-3	1 - - - - - X -	NA	S.G. HYD. SHOCK SUPPRESSORS
690290	TBX-RCPCSG-02-SM2 A26 B59RB	F-C NOTE 1	VT-3	1 - - - - - X -	NA	S.G. HYD. SHOCK SUPPRESSORS, PD14856. TDLR VERIFICATION BOUNDARY.

REACTOR COOLANT TBX-RCPCSG-03

690300	TBX-RCPCSG-03-S1 A27 B12RB	F-C NOTE 1	VT-3	1 - - - - - X -	NA	S.G. COLUMN SUPPORT, 1457F29. TDLR VERIFICATION BOUNDARY.
690325	TBX-RCPCSG-03-S2 A27 B12RB	F-C NOTE 1	VT-3	1 - - - - - X -	NA	S.G. COLUMN SUPPORT, 1457F29. TDLR VERIFICATION BOUNDARY.

ICR-5

pg 23 of 29

		INSPECTION INTERVAL	PLAN STATUS									PRESERVICE YEAR
			FIRST			SECOND			THIRD			
		ASME	PERIOD			PERIOD			PERIOD			
		SEC. XI	-----									
SUMMARY EXAMINATION AREA		CATGY	O U T A G E									INSTRUCTIONS
NUMBER IDENTIFICATION		ITEM NO METH	1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**

REACTOR COOLANT TBX-RCPSSG-03

690350	TBX-RCPSSG-03-S3 A27 812RB	F-C NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	NA	S.G. COLUMN SUPPORT. 1457F29. TDLR VERIFICATION BOUNDARY.
690375	TBX-RCPSSG-03-S4 A27 F12RB	F-C NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	NA	S.G. COLUMN SUPPORT. 1457F29. TDLR VERIFICATION BOUNDARY.
690400	TBX-RCPSSG-03-L1 A27 835RB	F-B NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	NA	S.G. LOWER LATERAL SUPPORT. 1457F31. LB-1. TDLR VERIFICATION BOUNDARY.
690425	TBX-RCPSSG-03-L2 A27 835RB	F-B NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	NA	S.G. LOWER LATERAL SUPPORT. 1457F31. LS-1. TDLR VERIFICATION BOUNDARY.
690450	TBX-RCPSSG-03-L3 A27 835RB	F-B NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	NA	S.G. LOWER LATERAL SUPPORT. 1457F31. LS-3. TDLR VERIFICATION BOUNDARY.
690500	TBX-RCPSSG-03-U1 A28 859RB	F-B NOTE 1	VT-3	1	-	-	(X)	-	-	-	-	X	NA	S.G. UPPER LATERAL SUPPORT. 1457F34. US-1. TDLR VERIFICATION BOUNDARY.
690520	TBX-RCPSSG-03-U2 A27 859RB	F-B NOTE 1	VT-3	1	-	-	(X)	-	-	-	-	X	NA	S.G. UPPER LATERAL SUPPORT. 1457F34. US-2. TDLR VERIFICATION BOUNDARY.

ICR-5

		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR	
					FIRST PERIOD			SECOND PERIOD			THIRD PERIOD				
		ASME			PERIOD			PERIOD			PERIOD				
		SEC. XI			-----			-----			-----				
SUMMARY EXAMINATION AREA		CATGY NDE			- - - - - O U T A G E - - - - -									INSTRUCTIONS	
NUMBER	IDENTIFICATION	ITEM NO METH			1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**	

REACTOR COOLANT TBX-RCPCSG-03

690540

TBX-RCESG-03-L3  
A27 B59RBF-B  
NOTE 1

VT-3



NA

S.G. UPPER LATERAL SUPPORT.  
1457F35. RING. TDLR  
VERIFICATION BOUNDARY.

690580

TBX-RCESG-03-SM1  
A28 B59RBF-C  
NOTE 1

VT-3



NA

S.G. HYD. SNUBBER. PD14856.  
TDLR VERIFICATION BOUNDARY.

690590

TBX-RCESG-03-SM2  
A28 B59RBF-C  
NOTE 1

VT-3



NA

S.G. HYD. SNUBBER. PD14856.  
TDLR VERIFICATION BOUNDARY.

ICR-5

REACTOR COOLANT TBX-RCPCSG-04

690600

TBX-RCESG-04-S1

F-C  
NOTE 1

VT-3

1 - - - - X - - - -

NA

S.G. COLUMN SUPPORT. 1457F29.  
TDLR VERIFICATION BOUNDARY.

690625

TBX-RCESG-04-S2  
A29 B12RBF-C  
NOTE 1

VT-3

1 - - - - X - - - -

NA

S.G. COLUMN SUPPORT. 1457F29.  
TDLR VERIFICATION BOUNDARY.

690650

TBX-RCESG-04-S3  
A29 B12RBF-C  
NOTE 1

VT-3

1 - - - - X - - - -

NA

S.G. COLUMN SUPPORT. 1457F29.  
TDLR VERIFICATION BOUNDARY.

690675

TBX-RCESG-04-S4  
A29 B12RBF-C  
NOTE 1

VT-3

1 - - - - X - - - -

NA

S.G. COLUMN SUPPORT. 1457F29.  
TDLR VERIFICATION BOUNDARY.



		INSPECTION INTERVAL			PLAN STATUS									PRESERVICE YEAR					
					FIRST PERIOD			SECOND PERIOD			THIRD PERIOD								
		ASME																	
		SEC. XI																	
SUMMARY EXAMINATION AREA		CATGY			NDE			OUTAGE									INSTRUCTIONS		
NUMBER IDENTIFICATION		ITEM NO			METH			1 2 3			1 2 3			1 2 3			**CALIBRATION BLOCK**		

FEEDWATER 6-FW-1-09B-1303-2

741000	TBX-2-2402-H33 FW-1-09B-012-C62K R30 B65RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.
741100	TBX-2-2402-H32 FW-1-09B-013-C62K R30 B66RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.
741200	TBX-2-2402-H35 FW-1-09B-014-C62S R30 B62RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SPRING. TDLR VERIFICATION BOUNDARY.
741300	TBX-2-2402-H37 FW-1-09B-015-C62K R30 B65RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.
741400	TBX-2-2402-H36 FW-1-09B-016-C62K R30 B63RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.
741500	TBX-2-2402-H38 FW-1-09B-017-C62S R30 B69RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	-	-	-	NA	SPRING. TDLR VERIFICATION BOUNDARY.
741550	TBX-2-2402-H38 FW-1-09B-017-C62S R30 B69RB	C-C C3.20	MT	1	-	-	-	-	-	-	-	-	-	X	-	-	NA	4-1" LUGS. TDLR VERIFICATION BOUNDARY.

ICR-5

		INSPECTION INTERVAL	PLAN STATUS									PRESERVICE YEAR	
			FIRST			SECOND			THIRD				
		ASME	PERIOD			PERIOD			PERIOD				
		SEC. XI	-----			-----			-----				
SUMMARY EXAMINATION AREA		CATGY	MDE	- - - - - O U T A G E - - - - -									INSTRUCTIONS
NUMBER	IDENTIFICATION	ITEM NO	METH	1	2	3	1	2	3	1	2	3	
													**CALIBRATION BLOCK**

FEEDWATER 6-FW-1-098-1303-2

741600 TBX-2-2402-H34  
FW-1-098-700-C62K  
R30 B65RB

F-C  
NOTE 1

VT-3

1 - - X - - - - X -

NA SNUBBER, TDLR VERIFICATION  
BOUNDARY.

ICR-5

741650 TBX-2-2402-H34  
FW-1-098-700-C62K  
R30 B65RB

C-C  
C3.20

MT

1 - - - - - X -

NA B-1" LUGS, TDLR VERIFICATION  
BOUNDARY.

741700 TBX-2-2402-H2B  
FW-1-098-701-C62R  
R30 B72RB

F-C  
NOTE 1

VT-3

1 - - X - - - - -

NA STRUT, TDLR VERIFICATION  
BOUNDARY.

741800 TBX-2-2402-H10  
FW-1-098-702-C62K  
R14 B64RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - -

NA SNUBBER, TDLR VERIFICATION  
BOUNDARY.

741900 TBX-2-2402-H9  
FW-1-098-702-C62R  
R100AB65SB

F-C  
NOTE 1

VT-3

1 - C - - - - -

NA STRUT, TDLR VERIFICATION  
BOUNDARY.

FEEDWATER 6-FW-1-099-1303-2

742000 TBX-2-2102-H32  
FW-1-099-001-C62S  
R14 B68RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - -

NA SPRING, TDLR VERIFICATION  
BOUNDARY.

742100 TBX-2-2102-H31  
FW-1-099-002-C62R  
R14 B68RB

F-C  
NOTE 1

VT-3

1 - - - - - X - - -

NA STRUT, TDLR VERIFICATION  
BOUNDARY.

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATGY NDE ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	INSTRUCTIONS **CALIBRATION BLOCK**
					FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
		1	2	3	1	2	3		

FEEDWATER 6-FW-1-100-1303-2

743300 TBX-2-2202-H47 F-C VT-3 1 - - - - - X - - - NA SNUBBER. TDLR VERIFICATION  
FW-1-100-007-C52K NOTE 1 BOUNDARY.  
R35 B53RB

743400 TBX-2-2202-H48 F-C VT-3 1 - - X - - - - - NA SPRING. TDLR VERIFICATION  
FW-1-100-008-C52S NOTE 1 BOUNDARY.  
R13 B53RB

743500 TBX-2-2202-H49 F-C VT-3 1 - - (X) X - - - - - NA SNUBBER. TDLR VERIFICATION  
FW-1-100-701-C52K NOTE 1 BOUNDARY.  
R13 B53RB

743600 TBX-2-2202-H65 F-C VT-3 1 - - (X) X - - - - - NA SNUBBER. TDLR VERIFICATION  
FW-1-100-702-C52K NOTE 1 BOUNDARY.  
R13 B55RB

743650 TBX-2-2202-H65 C-C WT 1 - - - X - - - - - NA 8-1" LUGS. TDLR VERIFICATION  
FW-1-100-702-C52K CS.20 BOUNDARY.  
R13 B55RB

FEEDWATER 6-FW-1-101-1303-2

743700 TBX-2-2302-H56 F-C VT-3 1 - - - - - X - - - NA STRUT. TDLR VERIFICATION  
FW-1-101-001-C62R NOTE 1 BOUNDARY.  
R14 B64RB

743800 TBX-2-2302-H55 F-C VT-3 1 - - - - - X - - - NA STRUT. TDLR VERIFICATION  
FW-1-101-002-C62R NOTE 1 BOUNDARY.  
R14 B64RB

ICR-5

INSPECTION INTERVAL		PLAN STATUS									PRESERVICE YEAR	INSTRUCTIONS
		ASNE	SEC. XI	CATGY	NDE	ITEM	NO	METH	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
SUMMARY EXAMINATION AREA		----- O U T A G E -----										
NUMBER	IDENTIFICATION								1	2	3	

\*\*CALIBRATION BLOCK\*\*

FEEDWATER 6-FW-1-101-1303-2

743900	TBX-2-2302-H54 FW-1-101-003-C62R R14 864RB	F-C NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	-	NA	STRUT. TDLR VERIFICATION BOUNDARY.
744000	TBX-2-2302-H53 FW-1-101-004-C62R R14 864RB	F-C NOTE 1	VT-3	1	-	-	-	-	-	X	-	-	-	NA	STRUT. TDLR VERIFICATION BOUNDARY.
744100	TBX-2-2302-H51 FW-1-101-005-C52R R13 856RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	NA	STRUT. TDLR VERIFICATION BOUNDARY.
744200	TBX-2-2302-H52 FW-1-101-006-C52R R13 856RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	NA	STRUT. TDLR VERIFICATION BOUNDARY.
744300	TBX-2-2302-H50 FW-1-101-007-C52K R13 853RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.
744400	TBX-2-2302-H49 FW-1-101-008-C52S R13 853RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	NA	SPRING. TDLR VERIFICATION BOUNDARY.
744500	TBX-2-2302-H58 FW-1-101-009-C52K R13 857RB	F-C NOTE 1	VT-3	1	-	-	X	-	-	-	-	-	-	NA	SNUBBER. TDLR VERIFICATION BOUNDARY.

ILR-5

ISI-1R2-002	Appendix C	Add Code Case N-416 "Alternative Rules for Hydrostatic Testing of Repair or Replacement of Class 2 Piping"
	Section 5 Table 9	Add reference to Note 7 on page 100 and add Note 7 to note page.
ISI-1R2-003	Section 2	Revised the following drawings: CC - Sh. 3 CT - Sh. 3, 4 DD - Sh. 2 DO - Sh. 1, 2 SI - Sh. 7, 8, 9
	Section 5	Replace the following pages from Table 9: 58, 86, 96, 101, 102, 107, 110, 112, 113, 149, 158
ISI-1R2-004	Appendix C	Add Code Case N-457 "Qualification Specimen Notch Location for Ultrasonic Examination of Bolts and Studs"
	Section 4.1	Replace the following pages: 51, 52, 53 Add the following pages: 37.1, 45.1, 51.1, 62.1
ISI-1R2-005	Section 4.1, 4.2	Replace pages: 4-2, 9, 11, 16, 17, 19, 24, 25, 26, 31, 32, 39, 54, 140, 145, 147, 189, 190, 191, 261, 262, 265, 266 Add page 54.1, 93.1, 96.1, 96.2