

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

November 26, 1975

R. S. Boyd, Acting Director
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555


Dear Mr. Boyd:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No DPR-22

Maladjustment in #12 Diesel Generator Fast Start Control
Improper Setting on APR Time Delay Relay
TIP Ball Valve Failure to Close
RCIC Steam Control Valve Stuck Closed

Licensee Event Reports for the 4 occurrences identified above are attached to this letter.

Yours very truly,



L. O. Mayer, PE
Manager, Nuclear Support Services

LOM/MHV/deb

cc: J. G. Keppler
G. Charnoff
MPCA
Attn: J. W. Ferman

9105070355 751126
CF ADOCK 05000263
CF