



GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775
AREA CODE 504 435 8094 346 8651

*December 6, 1993

RBG- 39535

File Nos. G9.5, G9.25.1.3

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

SUBJECT: River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47
Licensee Event Report 50-458/93-025-00

Gentlemen:

In accordance with 10CFR50.73(a)(2)(i)(B), enclosed is the subject report concerning an event in which train B of the residual heat removal system was improperly rendered inoperable while the high pressure core spray system was out of service, resulting in an inadvertent entry into Technical Specification 3.0.3, since this specific emergency core cooling system (ECCS) configuration is not addressed by the plant Technical Specifications.

Very truly yours,

James J. Fisicaro
Manager - Safety Assessment
and Quality Verification
River Bend Nuclear Group

Enclosure

140027

IF22
11

cc: U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

INPO Records Center
1100 Circle Parkway
Atlanta, GA 30339-3064

Mr. C.R. Oberg
Public Utility Commission of Texas
7800 Shoal Creek Blvd., Suite 400 North
Austin, TX 78757

Louisiana Department of Environmental Quality
Nuclear Energy Division
P.O. Box 82135
Baton Rouge, LA 70884-2135
ATTN: Administrator