



**New York Power  
Authority**

**Ralph E. Beedle**  
Executive Vice President  
Nuclear Generation

September 28, 1993  
JPN-93-070

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Proposed Change to the Technical Specifications  
ESW Pump Surveillance Testing (JPTS-93-002)

REFERENCE: 1. NRC letter, C. W. Hehl to W. Fernandez, dated  
October 9, 1990, "Results of the August 21, 1990  
Enforcement Conference."

Dear Sir:

This application for an Amendment to the James A. FitzPatrick Technical Specifications proposes to revise Emergency Service Water System (ESWS) pump Surveillance Requirement 4.11.D.1. The proposed change addresses the limitations of the "shut off head" ESW pump surveillance test currently required by the FitzPatrick Technical Specifications. The proposed surveillance test would add a flow requirement and test the pump in accordance with the FitzPatrick Inservice Testing Program which is designed to address appropriate portions of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (B&PV) Code. To add operational flexibility, the Authority has also revised pump flow rate requirements based on changes to the system alignment, revised heat load calculations and revised component flow requirements.

This submittal satisfies a commitment (Reference 1) to improve the ESW pump surveillance test.

The signed original of the Application for Amendment to Operating License is enclosed for filing. The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II. A markup of the affected Technical Specification pages is included as Attachment III.

040098


9310050133 930928  
PDR ADOCK 05000333  
P PDR

A047  
11

A copy of this application and the associated attachments are being provided to the designated New York State official in accordance with 10 CFR 50.91.

If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,



Ralph E. Beedle

att: as stated

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. Brian C. McCabe  
Project Directorate I-1  
Division of Reactor Projects - I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14 B2  
Washington, DC 20555

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16<sup>th</sup> Floor  
Albany, NY 12223