



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

Robert A. Fenech
Vice President, Sequoyah Nuclear Plant

September 28, 1993

TVA-SQN-TS-93-10

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS) CHANGE 93-10,
"FIRE PROTECTION"

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change revises various fire protection specifications to (1) clarify operability requirements regarding fire suppression system flowpath, (2) delete special reporting requirements, and (3) incorporate additional guidance into a TS action requirement for spray and/or sprinkler systems inside containment.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

TVA views the current special reporting requirements as an undue burden on the facility. Therefore, TVA requests an expeditious review of the enclosed amendment request. TVA requests a 45-day implementation period for this TS change following issuance.

040035

9310050215 930928
PDR ADOCK 05000327
P PDR

ADOCK

U.S. Nuclear Regulatory Commission

Page 2

September 28, 1993


Please direct questions concerning this issue to D. V. Goodin at
(615) 843-7734.

Sincerely,



Robert A. Fenech

Sworn to and subscribed before me
this 28th day of September 1993



Notary Public

My Commission Expires 2/8/97

Enclosures

cc (Enclosures):

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
3rd Floor
L & C Annex
401 Church Street
Nashville, Tennessee 37243-1532

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711