

PROPOSED PAGE CHANGE

9008130079 900801
PDR ADOCK 05000341
P FDC

TABLE 3.3.3-3

EMERGENCY CORE COOLING SYSTEM RESPONSE TIMES

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)</u>
1. <u>CORE SPRAY SYSTEM</u>	
a. Reactor Vessel Low Water Level - Level 1.	<30
b. Drywell Pressure-High	<30
c. Reactor Steam Dome Pressure-Low	NA*
d. Manual Initiation	NA
2. <u>LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM</u>	
a. Reactor Vessel Low Water Level - Level 1	< 30
b. Drywell Pressure - High	< 30
c. Reactor Steam Dome Pressure - Low	NA*
d. Reactor Vessel Low Water Level - Level 2	NA
e. Reactor Steam Dome Pressure - Low	NA
f. Riser Differential Pressure - High	NA
g. Recirculation Pump Differential Pressure - High	NA
h. Manual Initiation	NA
3. <u>HIGH PRESSURE COOLANT INJECTION SYSTEM</u>	
a. Reactor Vessel Low Water Level - Level 2	< 30
b. Drywell Pressure - High	NA
c. Condensate Storage Tank Level-Low	NA
d. Reactor Vessel Water Level-High, Level 8	NA
e. Suppression Pool Water Level-High	NA
f. Manual Initiation	NA
4. <u>AUTOMATIC DEPRESSURIZATION SYSTEM</u>	
a. Reactor Vessel Low Water Level - Level 1	NA
b. Drywell Pressure-High	NA
c. ADS Timer	NA
d. Core Spray Pump Discharge Pressure-High	NA
e. RHR LPCI Mode Pump Discharge Pressure-High	NA
f. Reactor Vessel Low Water Level - Level 3	NA
g. Manual Initiation	NA
h. Drywell Pressure - High Bypass Timer	NA
i. Manual Inhibit	NA
5. <u>LOSS OF POWER</u>	
a. 4.16 kV Emergency Bus Undervoltage (Loss of Voltage)	NA
b. 4.16 kV Emergency Bus Undervoltage (Degraded Voltage)	NA

55
55

1

*These are permissive signals only. They do not activate ECCS initiation.