

INSERTS FOR PROPOSED CHANGES

INSERT 1

1

INSERT 2

80

INSERT 3

##

INSERT 4

- * Average bulk pool temperature
- ** Acoustic monitoring and tailpipe temperature
- # High range noble gas monitors
- ## One channel consists of the open limit switch, and the other channel consists of the closed limit switch

INSERT 5

ACTION 80 -

- a. With the number of OPERABLE channels less than the Required Number of Channels shown in Table 3.3.7.5-1, restore the inoperable channel to OPERABLE status within 30 days, or immediately initiate actions in accordance with Specification 6.9.2.
- b. With the number of OPERABLE channels less than the Minimum Number of Channels shown in Table 3.3.7.5-1, (except for the Primary Containment Hydrogen/Oxygen Concentration Analyzer and Monitor and the Drywell Atmosphere Post Accident Radiation Monitor) restore at least one inoperable channel to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN in the following 24 hours.
- c. With the number of OPERABLE Primary Containment Hydrogen/Oxygen Concentration Analyzer and Monitor channels less than the Minimum Number of Channels requirement shown in Table 3.3.7.5-1, restore at least one inoperable channel to OPERABLE status within 72 hours, or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN in the following 24 hours.
- d. With the number of OPERABLE Drywell Atmosphere Post Accident Radiation Monitor channels less than the Minimum Number of Channels requirement shown in Table 3.3.7.5-1, initiate action in accordance with ACTION 81, below.

ACCIDENT MONITORING INSTRUMENTATION
ACTION STATEMENTS

INSERT 5

~~ACTION 30 -~~

- ~~a. With the number of OPERABLE accident monitoring instrumentation channels less than the Required Number of Channels shown in Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.~~
- ~~b. With the number of OPERABLE accident monitoring instrumentation channels less than the Minimum Channels OPERABLE requirements of Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.~~

ACTION 31 - With the number of OPERABLE accident monitoring instrumentation channels less than required by the Minimum Channels OPERABLE requirement, either restore the inoperable channel(s) to OPERABLE status within 72 hours, or:

- a. Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
- b. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.

ACTION 82 -

- a. With the number of OPERABLE accident monitoring instrumentation channels less than the Required Number of Channels shown in Table 3.3.7.5-1, verify the valve(s) position by use of alternate indication methods. If the affected penetration is not isolated by either (i) a closed manual valve, (ii) a blind flange, or (iii) a deactivated automatic valve located outside primary containment, restore the inoperable channel(s) to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels less than the Minimum Channels OPERABLE requirements of Table 3.3.7.5-1, verify the valve(s) position by use of alternate indication methods. If the affected penetration is not isolated by either (i) a closed manual valve, (ii) a blind flange, or (iii) a deactivated automatic valve located outside primary containment, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.