

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2.1 A minimum of one pressurizer code safety valve shall be OPERABLE with a lift setting of 2485 PSIG $\pm 1\%$ ^{3%}

APPLICABILITY: MODES 4 and 5.

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE residual heat removal loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

~~4.4.2.1 No additional Surveillance Requirements other than those required by Specification 4.0.5.~~

*THE SURVEILLANCE REQUIREMENTS OF SPECIFICATION 4.0.5, SHALL
BE MET, OR;*

*THE PRESSURIZER CODE SAFETY VALVE SHALL HAVE ITS LIFT SET
PRESSURE VERIFIED UNDER COLD CONDITIONS,*

~~*The lift setting pressure shall correspond to ambient conditions of the valve
at nominal operating temperature and pressure.~~

REACTOR COOLANT SYSTEM

OPERATING

LIMITING CONDITION FOR OPERATION

3.4.2.2 All pressurizer code safety valves shall be OPERABLE with a lift setting of 2485 PSIG \pm ~~1%~~ ^{3%} *

APPLICABILITY: MODES 1, 2 and 3.*

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.

SURVEILLANCE REQUIREMENTS

4.4.2.2 No additional Surveillance Requirements other than those required by Specification 4.0.5.

* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

MODE 3 APPLICABILITY IS EXEMPTED UNDER THE FOLLOWING CONDITIONS:

- 1. THERE HAS BEEN AT LEAST 5 DAYS OF OPERATION IN MODES 5 OR 6 SINCE THE REACTOR WAS LAST CRITICAL, AND*
- 2. ALL RCCAs ARE FULLY INSERTED WITH ALL CRDMs DE-ENERGIZED.*