Southern California Edison Company
23 PARKER STREET
IRVINE, CALIFORNIA 92718

J. L. RAINSBERRY
PLANT LICENSING MANAGER
SAN ONOFRE NUCLEAR GENERATING STATION

TELEPHONE
(714) 454-4552

November 4, 1993

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **Docket Nos. 50-361 and 50-362**
Response to NRC Bulletin 88-11, "Pressurizer Surge Line Thermal Stratification"
San Onofre Nuclear Generating Station
Units 2 and 3

NRC Bulletin No. 88-11, "Pressurizer Surge Line Thermal Stratification," requested that the addressees establish and implement a program to confirm pressurizer surge line integrity in view of the occurrence of thermal stratification. The Bulletin also required addressees to inform the staff of the actions taken to resolve this issue.

SCE has completed the required actions in response to NRC Bulletin No. 88-11. The actions taken show that the San Onofre Nuclear Generating Station Units 2 and 3 pressurizer surge lines meet the applicable ASME Code requirements for the 40 year service life of the units. The enclosed report documents in detail the response of SCE to all of the requirements of NRC Bulletin No. 88-11.

If you need additional information, please let me know.

Very truly yours,

J. L. Rainsberry

Enclosure

cc: B. H. Faulkenberry, Regional Administrator, NRC Region V
NRC Senior Resident Inspector's Office, San Onofre Units 1, 2 & 3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3

050022

IE30 1/1

9311080089 931104
PDR ADOCK 05000361
P PDR

State of California
SS.
County of Orange

By: J. L. Rainsberry
J. L. Rainsberry
Plant Licensing Manager

Subscribed and sworn to before me this 4th day of November, 1993.

Mariane Sanchez
Notary Public

OFFICIAL SEAL
MARIANE SANCHEZ
Notary Public-California
ORANGE COUNTY
My Commission Expires
October 14, 1994