LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 7 8 | 9 | I I L L S C 1 | 14 | (2) | 15 | 0 0 - 0 0 0 0 0 - 0 0 | 25 | (3) | 26 | 4 1 | 0 0 10 | (4) | 57 CAT 58 | (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE JO

CON'T

0 1 | 8 | REPORT SOURCE | L (6) | 60 | 0 5 0 0 0 3 7 3 (7) | 68 | 69 | 1 1 11 8 8 2 (8) | 74 | 75 | 1 2 0 3 8 2 (9) | 80

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On November 18, 1982 both doors into the Unit 1 Reactor Building on elevation 761'

0 3 | opened at the same time allowing an inflow of air to the reactor building. Although

0 4 | secondary containment was violated, negative pressure was maintained in the

0 5 | Reactor Building. In addition primary containment integrity

0 6 | was in effect at all times. The health and safety of the public was not affected.

0 7 |

0 8 | 7 8 9 80

0 9 | 7 8

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
X X (11)	E (12)	A (13)	X X X X X X (14)	X (15)	Z (16)
9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	1 5 5	/	0 3	L	—	0
	21 22	23	24 26	27	28 29	30	31	32

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	G (19)	Z (20)	Z (21)	0 0 0 0	Z (23)	N (24)	A (25)	X 9 9 9
33	34	35	36	37 40	41	42	43	44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this occurrence was that door 285 electric strike was out-of-adjustment.

1 1 | Therefore the latch bolt could not work properly. The electric strike was adjusted

1 2 | that afternoon so that the latch bolt worked properly.

1 3 |

1 4 | 7 8 9

FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
B (28)	0 3 0 (29)	NA	D (31)	NRC OBSERVATION
9	10 12	13 44	45	46 80

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z (33)	Z (34)	NA	NA
9	10 11 44		45 80

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION (39)
0 0 0 (37)	Z (38)	NA
9 11	12	13 80

PERSONNEL INJURIES

NUMBER	DESCRIPTION (41)
0 0 0 (40)	NA
9 11	12 80

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE	DESCRIPTION
Z (42)	NA
9	10 80

8212270356 821206
PDR ADOCK 05000373
S PDR

PUBLICITY

ISSUED	DESCRIPTION (45)
N (44)	NA
9	10 68

NRC USE ONLY

69 80

NAME OF PREPARER Diane L. Kay PHONE (815) 357-6761