NRC FORM 366 (12-81)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011 EXPIRES 4-30-82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | SCVC S 1 (2) | 00-000 00-00 (3) | 4 1 0 0 0 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000395 (7) | 120782 (8) | 122182 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On 12/07/82, with the Plant in Mode 1, a Fire Watch Patrol was not
03 executed for Zone FF, Roor 236-01, in the Intermediate Building from
04 1600 hours to 2000 hours. The Fire Watch had been implemented per
05 Technical Specification Action Statement as area smoke detectors were
06 inoperable. No adverse consequence resulted as adjacent area smoke
07 detectors remained operable; also the area is of very low fire
08 loading.

09 | SYSTEM CODE AB (11) | CAUSE CODE A (12) | CAUSE SUBCODE X (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 050 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION H (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER (26) Z999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The Shift Firewatch Leader departed the site early without notifying
11 the Operations Shift Supervisor. Another fire watch person failed to
12 report to work or call in. Subject personnel were dismissed.
13 The Licensee generated correspondence to inform all fire watch
14 personnel on correct absentee measures.

15 | FACILITY STATUS B (28) | % POWER 030 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Log Signoff Review

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

8212300042 821221
PDR ADOCK 05000395
S PDR

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER _____ PHONE: _____