

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1
---	---

 M S G G S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 37 CAT 38CON'T

0	1
---	---

 REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 1 1 2 7 8 2 8 1 2 2 2 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On November 27, 1982, the Meteorological Monitoring System was removed from service

0 3 for approximately 7.5 hours to perform work as required by design change package

0 4 82-457. An LCO was entered in accordance with T.S.3.3.7.3. This had no effect on

0 5 the health and safety of the public and did not constitute a threat to plant safety.

0 6 The event is being reported pursuant to T.S.6.9.1.13.b.

0 7

0 8

0	9
---	---

1	F	11	X	12	Z	13	X	X	X	X	X	X	14	Z	15	Z	16
---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----

17	8	2	1	4	5	0	3	L	0
----	---	---	---	---	---	---	---	---	---

X	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	N	24	Z	25	Z	9	9	9	26
---	----	---	----	---	----	---	----	---	---	---	---	---	----	---	----	---	----	---	---	---	---	----

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The event was caused by a planned maintenance outage. DCP 82-457 was implemented to

1 1 change breakers and circuit wires to meet NRC requirements. The system was restored

1 2 on November 27, at 1530 hours and the LCO was lifted. This is submitted as a final

1 3 report.

1 4

1	5
---	---

 B 28 0 0 0 29 NA 30 A 31 Planned Activity 32

1	6
---	---

 Z 33 Z 34 NA 35 NA 36

1	7
---	---

 0 0 0 37 Z 38 NA 39

1	8
---	---

 0 0 0 40 NA 41

1	9
---	---

 Z 42 NA 43

2	0
---	---

 44 NA 45

2	0
---	---

 46 NA 478212300200 821222
PDR ADOCK 05000416
S PDR

NAME OF PREFARER Original Signed by Ron Byrd

PHONE: _____