

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

0	1	A	L	J	M	F	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

CON'T

REPORT
SOURCE

REPORT SOURCE: 01 60 61 05 00 00 36 47 68 69 11 27 82 74 75 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 0820 on 11-27-82, Source Range Channel N-32 was declared inoperable due to a loss of detector voltage (Source Range Channel N-31 had previously been declared inoperable at 0645 on 11-27-82 due to a faulty high voltage power supply.) Tech. Spec. 3.3.1, in part, requires one Source Range Channel to be operable during plant shutdown. Tech. Spec. 3.3.1 action statement requirements were met. Health/safety of the public was not affected.

0	8		80
7	8	9	

0	9	I	A	11	E	12	A	13	I	N	S	T	R	U	14	E	15	Z	16		
7	8	9	10	11	12	13	18	19	20												
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.				OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
17		8	2		0	4	8	/	0	3	L		0								
21	22	23	24	25	26	27	28	29	30	31	32										
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER					
A	18	Z	19	Z	20	Z	21	0	0	0	N	23	Y	24	N	25	W	1	2	0	26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47							
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																					

1	0	This event was due to a faulty high voltage connector. Following replacement of the
1	1	connector and satisfactory completion of FNP-2-STP-41.1 (Source Range Functional Check
1	2	Channel N-32), Source Range Channel N-32 was declared operable at 1025 on 11-27-82.

1	3	
1	4	

FACILITY STATUS (28) 1 5 G 29 0 0 0 13 NA 30 31 A 32 Operational Event

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 Z 34

2 9 9 10 11

AMOUNT OF ACTIVITY (35)

NA

44

LOCATION OF RELEASE (36)

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
000	(40)	NA	

7		8		9		10		11		12	
		LOSS OF OR DAMAGE TO FACILITY		(43)		8212300227		821223			
		TYPE		DESCRIPTION		PDR		ADOCK		05000364	
1	9	Z	(42)	NA		S		PDR			

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
[2][0][N](44) NA
NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156