

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/1/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT
/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/8/ (7) /1/2/0/5/8/2/ (8) /1/2/2/2/8/2/ (9)
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On December 5, 1982, with Unit 1 at 20% power, channels FI-1475 and FI-1485 for /
/0/3/ / Steam Generator "A" and "B" Steam Flow respectively were indicating below the /
/0/4/ / actual flow. The redundant channels were operable and both channels were placed /
/0/5/ / in the tripped condition within one hour; therefore, the health and safety of the /
/0/6/ / general public were not affected. This event is within the Action Statement of /
/0/7/ / T.S. 3.3.2.1 and reportable pursuant to T.S. 6.9.1.9.a and b. /
/0/8/ /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /I/B/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ (14) /T/ (15) /Z/ (16)
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
REPORT NO. NO.
(17) NUMBER /8/2/ /-/ /0/8/4/ /-/ /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER

/E/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/
(26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The transmitter for FI-1475 was out of calibration low. The multiplier/divider /
/1/1/ / square root card was out of tolerance low for FI-1485. Both channels were satis- /
/1/2/ / factorily calibrated and returned to service within 52 hours. There are no /
/1/3/ / generic implications associated with this event. /
/1/4/ /

FACILITY METHOD OF
STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
/1/5/ /C/ (28) /0/2/0/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)
/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
/1/9/ /Z/ (42) / NA /
PDR ADOCK 05000338
S PDR

PUBLICITY
ISSUED DESCRIPTION (45)
/2/0/ /N/ (44) / NA /

NRC USE ONLY

NAME OF PREPARER W. R. CARTWRIGHT

PHONE (703) 894-5151