

**CONTROLLED**  
TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-2387  
Temporary Change Page 1 of 2

A. Procedure No. EP-R-034 Rev. 0  
Title Rx Bldg Sample Station Emerg Sampling

B. Requested Change

Attached

C. Reason For Change

NRC Appendix B item

Does this change alter the intent of the procedure? Yes ☐ No ☒  
Does this change identify an unreviewed safety question? Yes ☐ No ☒  
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes ☒ No ☐

E. Expiration Date NA

"N/A" for permanent status.  
45-60 days for temporary status

F. Initiator J. M. Rizzo

Title EP Specialist Date 11/22/82

G. Temporary Change Authorization

W. F. Shum 11/2-13/82  
Shift Supervision Date

L. D. M. 11/2/82  
Management Member Date

H. Temporary Change Approval

Approved as written for permanent status Yes ☐ No ☐

PORC Chairman/Section Head / Date /  
(As Applicable)

PORC Review / Date /  
(If Applicable) Mtg. No. /

/ Date /  
Superintendent of Plant

FORM AD-QA-101-2, Rev. 2 Page 1 of 1  
DUPLX

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, GO, N-4

Procedure and Page	Recommended Change
EP 1P-034 PAGE 8 of 11	Attachment B Action Step B-1.18- Add: The cask will be stored in the sample room next to the station.


Attach Additional Pages if Required

Priority: ☒ NRC Appendix B item 50-387/82-12-48

☐ A - Must be made immediately, Procedure is incorrect  
☐ B - Should be made soon, facilitates use of procedure  
☐ C - Should be made as time permits

JSR:ED - 11/16/82  
 Submitted

Disposition \_\_\_\_\_

  
 Approved - Mgr.-Nuclear Support

**CONTROLLED**  
TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-2385  
Temporary Change Page 1 of 2

A. Procedure No. EP-IP-034, Rev. 0  
Title Rx Rldg Sample Station Emergency Sampling

B.. Requested Change

Attached

C. Reason For Change

NRC Appendix B item 50-387/82-12-50

Does this change alter the intent of the procedure? Yes    No     
Does this change identify an unreviewed safety question? Yes    No     
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes    No   

E. Expiration Date ND "N/A" for permanent status.  
45-60 days for temporary status

F. Initiator JSR/ECO Title EP Specialist Date 12/2/82

G. Temporary Change Authorization  
[Signature] 12-13-82 [Signature] 12/3/82  
Shift Supervision Date Management Member Date

H. Temporary Change Approval

Approved as written for permanent status Yes    No   

PORC Chairman/Section Head    Date    PORC Review    Date     
(As Applicable) (If Applicable) Mtg. No.

   /     
Superintendent of Plant Date



**CONTROLLED**  
TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 22-2386  
Temporary Change Page 1 of 2

A. Procedure No. EP-IP-42 Rev. 0  
Title Chemistry Lab Emergency Preparation

B. Requested Change

Attached

C. Reason For Change

NRC Appendix B item

Does this change alter the intent of the procedure? Yes ☐ No ☒  
Does this change identify an unreviewed safety question? Yes ☐ No ☒  
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes ☒ No ☐

E. Expiration Date N/A "N/A" for permanent status.  
45-60 days for temporary status

F. Initiator MM220 Title EP Specialist Date 11/22/82

G. Temporary Change Authorization

W. L. Shum / 12-13-82 L. D. M. / 12/2/82  
Shift Supervision Date Management Member Date

H. Temporary Change Approval

Approved as written for permanent status Yes ☐ No ☐

PORC Chairman/Section Head /  
(As Applicable) Date

PORC Review /  
(If Applicable) Mtg. No. Date

\_\_\_\_\_  
Superintendent of Plant Date

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, GO, N-4

Procedure and Page	Recommended Change
EP IP 042 PAGE 4 of 6	<p>Add. the following between Action Steps <math>\Delta.1.1</math> and <math>\Delta.1.2</math>:</p> <p>NOTE: THE CHEMISTRY LABORATORY SHALL BE MONITORED AT ALL TIMES DURING SET-UP AND SAMPLE ANALYSIS. THE ECF CHEMISTRY LABORATORY WILL BE ACTIVATED AS THE ALTERNATE ANALYSIS FACILITY IF:</p> <p>(1) RADIATION LEVELS EXCEED 10 mR/HR. IN ANY PART OF THE LAB EXCEPT THE IMMEDIATE AREA OF THE SAMPLE LOCATION, OR</p> <p>(2) THE TURBINE BUILDING IS DECLARED AIR BORNE.</p> <p>ACTION STEPS <math>\Delta.1.2 - \Delta.1.10</math> WILL APPLY TO SET-UP OF THE ECF LABORATORY IF EITHER OF THE ABOVE CONDITIONS ARE MET.</p> <p>Attach Additional Pages if Required</p>

NRC Appendix B item 50-387/82-12-51

Priority: A - Must be made immediately, Procedure is incorrect  
 B - Should be made soon, facilitates use of procedure  
 C - Should be made as time permits

JS/1220 - 11/17/82  
 Submitted

Disposition \_\_\_\_\_

[Signature]  
 Approved - Mgr. - Nuclear Support



# CONTROLLED

## TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-2387  
Temporary Change Page 1 of 2

A. Procedure No. EP-IP-147, Rev. 0  
Title PASS LARGE LIQUID/DISSOLVED PASS SAMPLE

B. Requested Change

Attached

C. Reason For Change

NRC Appendix B item 50-387/82-12-5A

Does this change alter the intent of the procedure? Yes    No     
Does this change identify an unreviewed safety question? Yes    No     
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes    No   

E. Expiration Date N/A "N/A" for permanent status.  
45-60 days for temporary status

F. Initiator JM 1220 Title EP Specialist Date 11/19/82

G. Temporary Change Authorization

W. F. Shum 1/12-13-82 L. D. Miller 1/12/2/82  
Shift Supervision Date Management Member Date

H. Temporary Change Approval

Approved as written for permanent status Yes    No   

PORC Chairman/Section Head    Date    PORC Review     
(As Applicable) (If Applicable) Mtg. No.    Date   

   Superintendent of Plant    Date

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, CO, N-4

Procedure and Page	Recommended Change
EP IP 047 PAGE 15 OF 17	<ul style="list-style-type: none"> <li>• Change existing action step C-1.13 to C-1.14</li> <li>• Add action step C-1.13 -                Notify the TSC COORDINATOR of the results of the analysis</li> </ul>

Attach Additional Pages if Required

NRC Appendix B item 50-387/ 02-12-54 Part 3 of 3

Priority: A - Must be made immediately, Procedure is incorrect

B - Should be made soon, facilitates use of procedure

C - Should be made as time permits

JSR/220

Submitted

Disposition \_\_\_\_\_

[Signature]

Approved - Mgr. Nuclear Support



CONTROLLED

82-2355  
TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 23-85

Temporary Change Page 1 of 2

A. Procedure No. EP-IP-C46, Rev. 0  
Title PASS IODINE PARTICULATE SAMPLE

B. Requested Change

Detached

C. Reason For Change

NRC Appendix B item 50-387/02-12-54

Does this change alter the intent of the procedure? Yes    No     
Does this change identify an unreviewed safety question? Yes    No     
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes    No   

E. Expiration Date N/A

"N/A" for permanent status.  
45-60 days for temporary status

F. Initiator JH 1220

Title EP Specialist Date 11/19/82

G. Temporary Change Authorization

W F Shum 11-2-82  
Shift Supervision Date

LDOM 11/2/82  
Management Member Date

H. Temporary Change Approval

Approved as written for permanent status Yes    No   

PORC Chairman/Section Head    Date     
(As Applicable)

PORC Review    Date     
(If Applicable) Mtg. No.   

   Date     
Superintendent of Plant

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, GO, N-4

Procedure and Page	Recommended Change
EP 12046 PAGE 11 of 13	Attachment C • Add action step C.1.8- Notify the TSC COORDINATOR of the results of the analysis.

Attach Additional Pages if Required

Priority: A - NRC Appendix B item 50-387/E2-12-54 Part 2 of 3  
 - Must be made immediately, Procedure is incorrect  
 B - Should be made soon, facilitates use of procedure  
 C - Should be made as time permits

JSR/370  
 Submitted

Disposition \_\_\_\_\_

[Signature]  
 Approved - Mgr.-Nuclear Support

# TEMPORARY CHANGE APPROVAL FORM

Temporary Change Page 1 of 2

Title PASS 10 ml GAS SAMPLE

B.. Requested Change

Starchid

C. Reason For Change

NRC Appendix B item 50-387/82-12-54

Does this change alter the intent of the procedure? Yes      No       
Does this change identify an unreviewed safety question? Yes      No       
(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status Yes ☒ No ☐

E. Expiration Date 2/1

"N/A" for permanent status.  
45-60 days for temporary status

F. Initiator *1220*

Title GP Specialist Date 11/19/82

G. Temporary Change Authorization

W. F. Luper 112-13-82  
Shift Supervision Date

Management Member \_\_\_\_\_ Date \_\_\_\_\_

#### H. Temporary Change Approval

Approved as written for permanent status      Yes             No       

PORC Chairman/Section Head (As Applicable)	Date
---	------

PORC Review \_\_\_\_\_ / \_\_\_\_\_  
 (If Applicable) Mtg. No. \_\_\_\_\_ Date \_\_\_\_\_

Superintendent of Plant \_\_\_\_\_ Date \_\_\_\_\_

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, GO, N-4

Procedure and Page	Recommended Change
EP IP-045 PAGE 12 OF 14	Attachment C- <ul style="list-style-type: none"> <li>• Change existing action step C.1.13 to C.1.14</li> <li>• Add action step C.1.13-                Notify the TSC COORDINATOR of the results of the analysis.</li> </ul>


Attach Additional Pages if Required

Priority: A - NRC Appendix B item 50-387/82-12-54  
 - Must be made immediately, Procedure is incorrect Part 1 of 3  
 B - Should be made soon, facilitates use of procedure  
 C - Should be made as time permits

JSR

Submitted

Disposition \_\_\_\_\_

  
 Approved - Mgr.-Nuclear Support

# CONTROLLED

## TEMPORARY CHANGE APPROVAL FORM

Temporary Chg. No. 82-2390

Temporary Change Page 1 of 2

A. Procedure No. EP-1-001, Rev. 0

Title Emergency Classification

B. Requested Change

Attached

C. Reason For Change

Conformance with E-Plan Rev. 6  
Rectify deficiency identified during  
9/22/82 SSES alert.

Does this change alter the intent of the procedure? Yes ☐ No ☒

Does this change identify an unreviewed safety question? Yes ☐ No ☒

(See Reverse side of this page for procedure non-intent change and unreviewed safety question. If "yes" to either question, do not issue change without PORC review/Supt. approval, section 6.11.3)

D. Recommended for permanent status

Yes ☒ No ☐

E. Expiration Date

N/A

"N/A" for permanent status.

45-60 days for temporary status

F. Initiator

JSR

Title

EP Specialist

Date

11/29/82

G. Temporary Change Authorization

W.F. Shum

12-13-82

Shift Supervision

Date

LDM

Management Member

12/3/82

Date

H. Temporary Change Approval

Approved as written for permanent status

Yes ☐ No ☐

PORC Chairman/Section Head / Date /  
(As Applicable)

PORC Review / Date /  
(If Applicable) Mtg. No. /

Superintendent of Plant / Date /

## EP-IP CHANGE REQUEST

TO: MANAGER-NUCLEAR SUPPORT, GO, N-4

Procedure and Page	Recommended Change
EP IP 001 Page 25	<p>I. A. for the Alert changed to read:</p> <p>"Fire lasting more than 15 minutes and potentially affecting the safe shutdown of the plant."</p> <p>This change needs to be made to conform with Table 4.1 of the E-Plan and to conform with comments by PORC during review of the Plan and the 9/22/82 "Alert" activation of the Plan.</p> <p>Attach Additional Pages if Required</p>

Priority: A - Must be made immediately, Procedure is incorrect  
 B - Should be made soon, facilitates use of procedure  
 C - Should be made as time permits

C. L. Wike  
 Submitted

Disposition \_\_\_\_\_

[Signature]  
 Approved - Mgr.-Nuclear Support