



# Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

December 20, 1982

Mr. R.C. Haynes  
Director, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 82-056/03L-0  
ER 100450 FILE 841-23  
PLA- 1446

Docket No. 50-387  
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-056/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that one set of Drywell Vacuum Breakers were declared inoperable after failing to meet surveillance acceptance criteria.

H.W. Keiser  
Superintendent of Plant-Susquehanna

DGM/cw

cc: A. Schwencer  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8301030015 821220  
PDR ADDCK 05000387  
S PDR

*IEr*