

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6	7	8	9	0	1	2	3	4	5	6	7	8	9	0
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 C A S O S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
01 REPORT SOURCE L 0 5 0 0 0 3 6 1 7 1 1 1 5 8 2 8 1 2 1 5 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the plant in Mode 1, a review of operational surveillance records
03 revealed that the Reactor Coolant System (RCS) water inventory balance had not
04 been performed in 157 hours in violation of Technical Specification (TS) Section
05 4.0.2. Additionally, during this period, two plant startups from Mode 3 to 1
06 were made in violation of TS Section 4.0.4. There was no impact on plant
07 operation or the health and safety of plant personnel or the public, since the
08 total leakage from the inventory balance performed after discovery of the
09 omission was .4 gpm, there was no indication of leakage greater than this,
10 and all other RCS leakage surveillances were performed. (See also LER 82-156)

09 SYSTEM CODE C I 11 CAUSE CODE A 12 CAUSE SUBCODE A 13 COMPONENT CODE Z Z Z Z Z Z Z 14
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 2 23 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22
7 8 9 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 ATTACHMENT SUBMITTED N 23
7 8 9 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The RCS water inventory balance was properly scheduled by the Operations
11 Surveillance Group. However, the surveillance could not be performed on the
12 scheduled date because plant condition were not sufficiently stable and it was
13 not rescheduled. The surveillance was performed on November 15, 1982 and the
14 total leakage was .4 gpm. Shift supervisors have reviewed the circumstances
15 of this event and have been directed to integrate the surveillance into plant
16 operations. A shift surveillance sign-off system has been initiated.

15 FACILITY STATUS B 28 % POWER 0 3 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

8301030153 821215
PDR ADOCK 05000361
S PDR

NAME OF PREPARER

H. B. Ray

HB Ray / NRC member

PHONE

714/492-7700

NRC USE ONLY