

CONTROL BLOCK: 1 2 3 4 5 6 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 1 (2) 0 0 - 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) (5)

7 8 9 14 15 25 26 30 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

0 1

REPORT SOURCE L (6) 0 5 0 0 0 2 7 2 (7) 1 1 2 1 8 2 (8) 1 2 0 8 8 2 (9)

60 61 68 69 74 75 80

DOCKET NUMBER EVENT DATE REPORT DATE

0 2 On two separate occasions, on November 21 and December 4, 1982, during routine operation,

0 3 the control room operator discovered that the P-250 Computer was inoperable due to a

0 4 parity error. Since it utilizes the computer for inputs and calculations, the Reactor

0 5 Coolant System (RCS) subcooling monitor was declared inoperable and Action Statement

0 6 3.3.3.7a was entered. Wide range RCS temperature and pressure indications and steam

0 7 tables were available throughout the occurrence. The event constituted operation in a

0 8 degraded mode in accordance with Technical Specification 6.9.1.9b.

SYSTEM CODE I E 11		CAUSE CODE B 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE Y 15		VALVE SUBCODE Z 16	
LER RO REPORT NUMBER 17		EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 1 4 1		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN D 18		FUTURE ACTION F 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED Y 23	
NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER W 1 2 0 26							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	The malfunctions of the computer were apparently related with periodic increases in
1	1	ambient temperature due to insufficient ventilation. In each case, the computer
1	2	was reprogrammed and the action statement terminated. A temporary fan was
1	3	installed, improvement of the ventilation system is being investigated.

1	4															
7	8	9	BC													
FACILITY STATUS			% POWER			OTHER STATUS			(30)	METHOD OF DISCOVERY			DISCOVERY DESCRIPTION			(32)
1	5	(E)	(28)	0	8	1	(29)	N/A			(A)	(31)	Operator Observation			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	

ACTIVITY		CONTENT		RELEASED		OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF REL		USE	
1	6	Z	(33)	Z	(34)	N/A				N/A		(36)	

PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION	
1	7	0	0	0	37	Z	38 N/A

PERSONNEL INJURIES		41
NUMBER	DESCRIPTION	
1	2	3

7	8	9	10	11	12	N/A				80	
LOSS OF OR DAMAGE TO FACILITY (43)						8301030161 821208					
TYPE DESCRIPTION						PDR ADOCK 05000311					

1 9 Z 42 N/A S PDR
7 8 9 10 80
PUBLCITY NDC USE ONLY

ISSUED								DESCRIPTION (45)						NRC USE ONLY											
20		N		(44)	N/A																				
7	8	9		10	68						69	80													

NAME OF PREPARER R. Frahm

PHONE: (609) 935-6000 Ext 3078