

Duke Power Company
Nuclear Production Dept.
P.O. Box 1007
Charlotte, N.C. 28201-1007

M.S. Tuckman
Vice President
Nuclear Operations
(704)373-3851



DUKE POWER

March 13, 1991

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 1
Docket No. 50-413
Steam Generator Inspection Report

Pursuant to Technical Specifications 3/4.4.5.5 and 6.9.2, find attached the Catawba Unit 1 End-of-Cycle 4 Refueling Outage Steam Generator Inspection Report. Attachments 1, 3, 5, and 7 identify the tubes with imperfections, the imperfection location, and the size of the imperfection for Steam Generators A, B, C, and D respectively. Attachments 2, 4, 6, and 8 identify the tubes that were removed from service by plugging for Steam Generators A, B, C, and D respectively. There were 182 tubes plugged and zero tubes sleeved as a result of this inspection.

Very truly yours,

A handwritten signature in cursive script that reads "M. S. Tuckman".

M. S. Tuckman

Attachments

CRL26

9103200124 910313
PDR ADDCK 05000413
Q PDR

1/1
A001

U. S. Nuclear Regulatory Commission
March 13, 1991
Page 2

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, GA 30323

Mr. R. E. Martin
Office of Nuclear Reactor Regulations
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, DC 20555

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station