

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401
1750 Chestnut Street Tower II

December 22, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 2 - DOCKET
NO. 50-328 - FACILITY OPERATING LICENSE DPR-79 - REPORTABLE OCCURRENCE
REPORT SQRO-50-328/82134

The enclosed report provides details concerning the inoperability of one
refueling water storage tank (RWST) level channel. This report is submitted
in accordance with Sequoyah unit 2 Technical Specification 6.9.1.13.a.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Green
J. A. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

OFFICIAL COPY

8301030248 821222
PDR ADOCK 05000328
S PDR